



# **Assessing Nodal Adequacy of Large VRE Power Systems with New Adequacy Metrics Reflecting RA Contributions of G, T, & D**

**ESIG Fall Technical Workshop, October 2023  
San Diego, CA**

**Newton Energy Group:** Selin Yanikara, Alex Rudkevich

**Polaris Systems Optimization:** Russ Philbrick

**Tabors Caramanis Rudkevich:** Richard Tabors



# Traditional Resource Adequacy

## *Traditional*

- 1 Annual assessment of needs for capacity
- 2 Stylized power system models
- 3 Not applicable in the presence of transmission constraints
- 4 Do not capture the impacts of extreme weather events and common mode events
- 5 Do not capture the impact of operational flexibility
- 6 Used as a planning tool in determining capacity requirements and justify needs for investments in generation but not for transmission

## *Needs*

- 1 Decisions in many timeframes including short-term
- 2 Physically sound power system models
- 3 Locational economic signals provided to generation, transmission and demand that incorporate value of adequacy
- 4 Effects of extreme weather and common mode events
- 5 High operational details distinguishing flexible resources under non-recourse decisions
- 6 Planning tools and market design mechanisms facilitating co-optimization of investments in generation, transmission and demand-side technologies

# What Are the Needs to Assess the Impact of Extreme Market Events?


## *Traditional*

- 1 Annual assessment of needs for capacity
- 2 Stylized power system models
- 3 Not applicable in the presence of transmission constraints
- 4 Do not capture the impacts of extreme weather events and common mode events
- 5 Do not capture the impact of operational flexibility
- 6 Used as a planning tool in determining capacity requirements and justify needs for investments in generation but not for transmission

## *Needs*

- 1 Decisions in many timeframes including short-term
- 2 Physically sound power system models
- 3 Locational economic signals provided to generation, transmission and demand that incorporate value of adequacy
- 4 Effects of extreme weather and common mode events
- 5 High operational details distinguishing flexible resources under non-recourse decisions
- 6 Planning tools and market design mechanisms facilitating co-optimization of investments in generation, transmission and demand-side technologies

# Resource Adequacy Applied to Different Timeframes




**Week-ahead & Day-ahead:**  
Assessment of the adequacy of the fleet

**Day ahead & Intra-day:**  
Impacts of non-recourse decisions (commitment, dispatch of inflexible generation, deployment of demand response, etc.)

**Intra-day & Real-time:**  
Assessment of the adequacy of the reserve procurement policy


# All Decisions Have Reliability Impacts

Assessment of  
adequacy for **system**  
annual planning




Is there sufficient capacity  
available for Day-Ahead  
commitment?

*Weather Year 2000*



*Weather Year 2020*




Parallel Processing


- Risk locations and periods
- Generator performance
- Payment to participants for providing adequacy

# All Decisions Have Reliability Impacts

Annual assessment of adequacy for reserve procurement policy



Are there insufficient reserves to respond to contingencies or ability to replenish reserves in time?



# All Decisions Have Reliability Impacts

Assessment of adequacy  
for short term (2-5 day)  
system planning \*




Are there insufficient  
reserves to respond to  
contingencies or ability to  
replenish reserves in time?

*Monday Plan with  
Baseline Forecast*




**Repeat  
analysis daily**

*Weather Scenario 1*



*... other weather scenarios ...*

*Weather Scenario n*




Parallel Processing

\*Project under development  
funded by ARPA-E

# Shortage Is Local

System Load = 540 MW  
Generation Capacity = 600 MW

Limited transmission capacity from B to C causes load shed






# Shortage Is Local

System Load = 540 MW  
Generation Capacity = 600 MW

Load = 170 MW



Load shed sets the price to  
**VOLL=\$10,000/MWh**

Load 370 MW


Load reduction **35 MW**

**Adequacy Price = \$10,000**

*Generator B*  
Capacity = 200 MW  
Dispatch 200 MW

*Generator C*  
Capacity = 200 MW  
Dispatch = 105 MW  
**Adequacy Price = \$0**

# Operational Impact of Outages



Make commitment decisions for Tuesday, given the current stage of the grid (e.g., **Monday** outages)


*Not all outages are known!*

Respond to future outages subject to Monday's plan  
What flexibility do we have in the system?

*What is the reliability impact, subject to a base plan?*

# What Is Shortage, Anyways?


- Should **shortage** be limited to Load Shed?
  - What about reserve shortfalls, dispatch of demand response injectors, emergency purchases?
- Provide flexibility in defining shortage (near-misses) by detecting shortage economically




# An Annual Resource Adequacy Study of ERCOT



Annual study for 2024, each week processed in parallel with 100 outage samples per week



Nodal analysis with all major interfaces, 345 kV and 138 kV constraints



Single weather year study (2022): find weeks and locations with capacity needs




Reliability impact of day ahead decisions


# An Annual Resource Adequacy Study of ERCOT



Annual study for 2024, each week processed in parallel with 100 outage samples per week



Nodal analysis with all major interfaces, 345 kV and 138 kV constraints



Single weather year study (2022): find weeks and locations with capacity needs




Reliability impact of day ahead decisions

Turn-around time for this analysis: 3 hours  
Total Virtual Machine time: 88.5 hours

## Summary of Findings

- Shortage is location specific
  - Local shortages can occur regardless of capacity available elsewhere
- Operational policies and flexibility matter
- Changing grid conditions mean that traditional maintenance scheduling can lead to shortages without greater coordination and flexibility
- Severity and duration can be different


# Which Months Should We Focus Our Computational Efforts On?




*Based on both area and local shortage*

Is December the worst month for load shed?


### Monthly Peak Load




### Congestion Rent and Tx Violations



### Average Load and Generation Availability



### Load Shed in Weather Zones and Total Shortage






# Generator Performance for a Summer Month


## Normalized ELCC-d

August





powered by PSO



Significant contribution from storage resources



# How Dispersed Is Shortage?



# How Dispersed Is Shortage?




Consistent shortage in December with very little load shed. What is happening?

Local congestion due to combined impact of maintenance and forced outages, cannot be resolved through area level load shed

# How Local vs Widespread Is Shortage?

- How widespread or local is shortage?
- If equal to 1, shortage is system wide

$$\text{Shortage Localization Index} = \frac{\text{Total dispatch in shortage locations}}{\text{System dispatch}}$$




Total system dispatch during shortage = 505 MW

Total dispatch in locations with shortage = 200 MW (Bus B)

Shortage Localization Index = 0.40

# How Local vs Widespread Is Shortage?



# How Much Generation is Exposed to Shortage?

**Generation Exposed to Shortage (MWh)**

|     | Hour  |       |       |       |       |       |       |       |       |       |       |       |       |        |        |       |       |       |       |       |       |       |       |       |
|-----|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|--------|--------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|     | 0     | 1     | 2     | 3     | 4     | 5     | 6     | 7     | 8     | 9     | 10    | 11    | 12    | 13     | 14     | 15    | 16    | 17    | 18    | 19    | 20    | 21    | 22    | 23    |
| Jan |       |       |       |       |       |       |       | 2,751 |       |       |       |       |       |        |        |       |       |       |       |       |       |       |       |       |
| Feb |       |       |       |       |       |       |       |       |       |       |       |       |       |        |        |       |       |       |       |       |       |       |       |       |
| Mar |       |       |       |       |       |       |       |       |       |       |       |       |       |        |        |       |       |       |       |       |       |       |       |       |
| Apr | 729   | 711   | 658   | 600   | 582   | 592   | 284   | 299   | 423   | 433   | 449   | 422   | 390   | 403    | 381    | 380   | 403   | 459   | 827   | 814   | 802   | 843   | 757   | 734   |
| May |       |       |       |       |       |       |       |       |       |       |       |       |       |        |        |       |       |       |       |       |       |       |       |       |
| Jun |       |       |       |       |       |       |       |       |       |       |       |       |       |        |        |       |       |       |       |       |       |       |       |       |
| Jul |       |       |       |       |       |       |       |       |       |       |       |       |       |        |        |       |       |       | 6,327 |       |       |       |       |       |
| Aug |       |       |       |       |       |       |       |       |       |       |       |       |       | 52,510 | 83,778 |       |       | 4,395 | 7,840 | 7,827 |       |       |       |       |
| Sep |       |       |       |       |       |       |       |       |       |       |       |       |       |        |        |       |       |       |       |       |       |       |       |       |
| Oct |       |       |       |       |       |       |       |       |       |       |       |       |       |        |        |       |       |       |       |       |       |       |       |       |
| Nov |       |       |       |       |       |       |       |       |       |       |       |       |       |        |        |       |       |       |       |       |       |       |       |       |
| Dec | 1,074 | 1,047 | 1,048 | 1,444 | 1,818 | 1,807 | 1,791 | 1,857 | 1,842 | 1,789 | 1,839 | 1,856 | 1,840 | 1,828  | 1,774  | 2,054 | 2,376 | 2,432 | 2,527 | 2,585 | 2,590 | 2,560 | 2,475 | 2,458 |

## Shortage Definition

### Detect Events Other Than Load Shed

**Shortage hours x locations (August)**

***Hour***

|   |   |   |   |   |   |   |   |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|---|---|---|---|---|---|---|---|---|---|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| 0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 |
|---|---|---|---|---|---|---|---|---|---|----|----|----|----|----|----|----|----|----|----|----|----|----|----|

**Shortage 4,850**

**Price**

**Threshold 3,200**

|      |       |     |     |     |     |     |
|------|-------|-----|-----|-----|-----|-----|
| 6.7  | 79.4  |     | 0.2 | 0.6 | 0.6 |     |
| 16.1 | 129.6 | 0.3 | 7.0 | 6.8 | 6.8 | 0.1 |



More shortage

**Total expected load shed (MW) (August)**

***Hour***

|   |   |   |   |   |   |   |   |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|---|---|---|---|---|---|---|---|---|---|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| 0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 |
|---|---|---|---|---|---|---|---|---|---|----|----|----|----|----|----|----|----|----|----|----|----|----|----|

**Shortage 4,850**

**Price**

**Threshold 3,200**

|      |      |     |     |
|------|------|-----|-----|
| 13.7 | 85.9 | 1.5 | 4.0 |
| 13.7 | 85.9 | 1.5 | 4.0 |

**Same load shed**


# Shortage Definition

## Detect Events Other Than Load Shed

Shortage hours x locations



0 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23

Hour



Shortage 4,850  
Price  
Threshold 3,200


Shortage event due to reserve shortfalls and/or congestion price:






# Two Different Days (Reasons) With Shortage Price Heatmap

*Low availability + High load*



- Load shed in multiple areas with varying degree
- High adequacy price throughout
- Availability issue

*Local congestion driven shortage*




- Transmission violation due to simultaneous maintenance of units at the same location, combined with unplanned outages
- Cannot be resolved by area level load shed
- Staggering maintenance at this location resolves shortage!

# Solution Methodology: Probabilistic World of Resource Adequacy


What about weather?  
Outages are not the  
only contingency

RA




# Solution Methodology: Probabilistic World of Resource Adequacy

How to efficiently evaluate  
10,000s of scenarios?




# Computational Efficiency


*How to balance statistical significance and computational requirements?*



# Computational Efficiency



# Integrated Scenario Reduction: Random Outage Draws



# Stratified Sampling For Weather and Time Dimension

Parallel Processing


Outage Samples

Weather  
Scenario 1




*Outage sample  
with shortage*


Weather  
Scenario 2



Weather  
Scenario 3





Weather  
Scenario n



This scenario is clearly not critical. Can we detect this without spending heavy computational effort on this scenario?



# Stratified Sampling For Weather and Time Dimension

Outage Samples



Allocate more outage samples to critical weather scenarios

Based on variance of shortage probability estimate



No additional samples for the non-critical scenario

Weather Scenario n


Parallel Processing

Parallel Processing



# Stratified Sampling for ERCOT


100 outage draws x 52 weeks = 5200 samples



Turn-around time: 3 hours

100 outage draws x 52 weeks = 5200 samples

Additional samples: 2700 draws /week



Turn-around time: 3 + 8 hours = 11 hours

# In Summary

- Resource Adequacy can assess impacts on a **physically detailed** and **operationally accurate** model of energy systems:
  - Powerflow constraints and contingency analysis,
  - Unit commitment,
  - Storage, ramping, emissions, and a wide range of other physical and system constraints
- Assessment is both for **planning** and **operational** studies
- **Operational details** impact study outcomes (not all outages are known in advance, and not all decisions are flexible)
- We illustrated inclusion of transmission model with unit commitment and storage optimization
  - Other modeling options:
    - Impacts from any non-recourse decisions on later reliability
    - Sharing with neighbors in multi-footprint models
    - Impacts from other energy systems (gas supply limitations)
    - Load participation and impacts of changing policies (e.g., retail rate design)