




# Progress on the National Transmission Planning Study

**David Palchak**  
**NREL**  
ESIG 2023 Spring Workshop




## Objectives

- Identify **interregional and national strategies** to accelerate cost effective decarbonization
- Inform regional and interregional transmission planning processes, particularly by **engaging stakeholders**
- Identify **viable and efficient transmission options** that will provide **broad-scale benefits**




# Integrated Transmission Planning Approach






# Capacity expansion scenarios

Recap from updates  
Patrick Brown provided in  
Fall 2022 workshop




# Scenario Framework


## 4 transmission options




Limited



AC




HVDC  
Point-to-  
point



HVDC  
Multi-  
terminal



# Scenario Framework: 24 core scenarios

## 4 transmission options X 3 emissions-demand combinations





← Demand Growth →

↑ Emissions Target ↓	Current Policies <b>Low Demand</b>	Current Policies <b>High Demand</b>
	<b>90-by-2035</b> Low Demand	<b>90-by-2035</b> High Demand
	<b>100-by-2035</b> Low Demand	<b>100-by-2035</b> High Demand



# Scenario Framework: ~200 scenarios and sensitivities



4 transmission options X 3 emissions-demand combinations X 14 sensitivities



- Sensitivity**
- Transmission costs
  - NG prices (higher, lower)
  - PV and battery costs
  - Wind costs
  - Land-based RE siting
  - DER adoption
  - Interruptible load
  - Clean fuel (e.g., H<sub>2</sub>) prices (higher, lower)
  - Technologies included (expanded, limited)
  - Climate change impacts
  - Combined pessimistic



# Recap: Takeaways from capacity expansion modeling so far

Most scenarios point to RE, storage, and transmission capacities many times larger than today.




# Recap: Takeaways from capacity expansion modeling so far

Most scenarios point to RE, storage, and transmission capacities many times larger than today.




## Decarbonization driven by wind and solar deployment




# Recap: Takeaways from capacity expansion modeling so far


Most scenarios point to RE, storage, and transmission capacities many times larger than today.



Decarbonization driven by wind and solar deployment



Transmission is added nationwide, but with the highest density between the wind belt and eastern interconnection demand centers.





Interim results  
Do not distribute





## Current progress report: transitioning to nodal modeling

Jarrad Wright and Leonardo Rese have produced the technical work being presented






# Scenario Framework: 168 sensitivities

4 transmission options X 3 emissions-demand combinations X 14 sensitivities



- Sensitivity**
- Transmission costs
  - NG prices (higher, lower)
  - PV and battery costs
  - Wind costs
  - Land-based RE siting
  - DER adoption
  - Interruptible load
  - Clean fuel (e.g., H<sub>2</sub>) prices (higher, lower)
  - Technologies included (expanded, limited)
  - Climate change impacts
  - Combined pessimistic

# The evolution of capacity, demand, and transmission in this scenario are transformative




# New wind and solar PV capacity disaggregation


Scenario 1 (2035)	Number of POIs	2035 Capacity
Utility-scale solar	715	718 GW
Land-based wind	634	590 GW
Offshore Wind	16	42 GW

**Installed capacity (2022):**  
Solar PV ~140 GW (solar PV),  
Land-based wind ~135 GW  
Offshore wind ~0.04 GW

Map showing points of interconnection (POIs), not actual sites





# Interregional (Zonal) Transmission Capacity Expansion



# Interregional (Zonal) Transmission Capacity Expansion needs

Scenario 1 - 2020 to 2035



## Transmission expansion methods summarized


1. Disaggregate generation/storage capacity and demand based on CEM
2. Start running nodal PCM:
  - Unbounded (allow transmission overloads)
  - Semi-bounded (interface limits in selected locations)
  - Constrained (enforce everything at HV)
3. Transfer results to DCPF (snapshots):
  - Iterative transmission expansion with representative snapshots aimed at reducing overloading (with an interregional focus)
  - Use CEM transmission expansion as a guide for scale and general location
4. When overloading is greatly reduced, re-run fully constrained PCM for feasibility and to check if results are reasonable

# DC power flow-aided transmission expansion

## Priority is addressing interregional

Round 0


Between rounds, decrease overloading on the underlying system and utilize the new transmission



# Transmission expansion configuration after iterative DCPF (Scenario 1 – EI)


Does the new transmission result in:

- Reduced VRE curtailment?
- Decreased production cost?
- Adequately used networks?
- Etc.



- 2nd 230 kV Line to Existing ROW
- 2nd 345 kV Line to Existing ROW
- - - 2nd 500 kV Line to Existing ROW
- 2nd 765 kV Line to Existing ROW
- New 500 kV Line, Double Circuit
- - - New 500 kV Line, Single Circuit
- New 765 kV Line, Double Circuit

## TRANSMISSION EXPANSION (NUMBER OF NEW LINES)



Interim results  
Do not distribute



# Transmission expansion configuration after iterative DCPF (Scenario 1 – EI)

## Many more steps:

1. analyze PCM results
2. contingency analysis (N-1)
3. validate builds
4. iterate with stakeholders
5. double check resource adequacy
6. run AC power flow
7. update some data
8. feedback learnings from round one
9. and on and on to round two



**TRANSMISSION EXPANSION (NUMBER OF NEW LINES)**



- 2nd 230 kV Line to Existing ROW
- 2nd 345 kV Line to Existing ROW
- 2nd 500 kV Line to Existing ROW
- 2nd 765 kV Line to Existing ROW
- New 500 kV Line, Double Circuit
- New 500 kV Line, Single Circuit
- New 765 kV Line, Double Circuit



## Key Takeaways

- Solving inter-regional transmission as a highest priority addresses a lot of the transmission buildout needs, but not all.
- Good alignment on transmission capacities between capacity expansion and production cost model
  - I.e., the investment decisions being made with zonal granularity hold up with detailed modeling
- Expecting wide variation between nodal scenarios – similarities will help with inter-regional priorities




## Next steps

# Next up in zonal to nodal


## Scenario 2

- Limited AC expansion
- Year: 2035
- High demand
- 90% decarbonization by 2035




## Scenario 3

- HVDC
- Year: 2035
- High demand
- 90% decarbonization by 2035



# Additional analyses underway





**Thank you**

David.Palchak@nrel.gov



  
**Pacific Northwest**  
NATIONAL LABORATORY

  
**NREL**  
NATIONAL RENEWABLE ENERGY LABORATORY

U.S. DEPARTMENT OF  
**ENERGY**