




Evaluating the Ability of Met Models to Characterize Daily Cycles in Wind Generation

Dev Millstein

Lawrence Berkeley National Laboratory

June 2023 – ESIG 2023 Meteorology and Market Design for Grid Services Workshop



ENERGY TECHNOLOGIES AREA
BERKELEY LAB

This work was funded by the U.S. Department of Energy under Contract No. DE-AC02-05CH11231. The views and opinions of the authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof, or The Regents of the University of California.

Temporal profiles of wind needed to integrate wind energy into the power system


Some example of the needs:

- Understand the value of wind plants
- Help choose sites for wind plants
- Plan for future procurements (from a utility perspective)
- Prepare electricity system resources
- Schedule battery storage charge and discharge
- Even inform research and design of new wind turbines
- Becomes more critical with deeper market penetration


- Both **forecasts of wind profiles** and **retrospective wind profiles** are needed!
- This **presentation focuses on modeled, retrospective profiles** of wind resources, not forecasts
 - ERA5, MERRA2, HRRR
- Biases and errors identified here provide important context for understanding and improving forecasts

The challenge: Publicly available observations at >50 m rare

- Tall tower locations – order TENS
- Wind plant locations – order THOUSANDS
- Surface wind speed observations provide limited insight into wind patterns at hub and tip height
- How do we assess how well meteorological models represent wind profiles if very few observational locations are available?
- Common approaches include:
 - Analysis of existing tall tower data
 - Intensive measurement campaigns
- Approach described here:
 - Use generation records themselves to evaluate meteorological models




Compare generation records to generation estimates



Details and limitations


- Wind speed to generation transformation a function of a simple power curve
 - Matches specific power for each plant
 - Will not account for wake losses, intra-plant variation, turbulence, wind shear, etc.
- Hourly data
- Plant-level generation and curtailment records available in ERCOT (Texas), but not elsewhere
- Regional generation and curtailment records available in all ISO/RTOs
- Generation records can contain errors
- Generation records do not differentiate between maintenance needs and wind variation



Example power curves and how they vary with specific power





ERCOT – Comparison across >100 wind plants

Davidson and Millstein, 2022, *Wind Energy*, DOI: 10.1002/we.2759
“Limitations of reanalysis data for wind power applications”




Error between modeled generation and recorded generation


- Errors = $(CF_{\text{Model}} - CF_{\text{Actual}})$
- Example:
 - Model CF = 50%
 - Actual CF = 30%
 - Error = 20%
- Mean errors across the set of plants shown in each panel
- Interest in this case is in the spread of the errors not average bias
 - Small overall biases shown here are likely to be swamped by losses
 - Bias analysis will be discussed in later slides




(a)




(b)





(c)



(d)








- **Averaging over time dampens differences between modeled and recorded capacity factors**
- **Probability of CF within $\pm 20\%$ CF of actual:**
 - ERA5 Daily: 99.1%
 - ERA5 Hourly: 78.0%
 - MERRA2 Daily: 97.0%
 - MERRA2 Hourly: 70.3%

MERRA2 bias shows strong diurnal cycle


Model RMSE lower during daytime

Model correlation improved during daytime



Sunrise = SolTime 0

— ERA5 — MERRA2



- Model correlation best during daytime in all seasons
- Winter nighttime the worst
- HRRR has the highest correlation
 - HRRR's high resolution does not solve winter nighttime woes

3 Take away points from ERCOT plant-level comparisons

1. Hourly correlation and RMSE worse during nighttime than daytime

- Several causes possible: We suspect model errors in boundary layer representation drive declining model performance during nighttime
 - Error metrics have a strong connection to sunrise
 - Boundary layer height lower at night than day


2. Correlation improves with model resolution (50 km > 30 km > 3 km)

- Hourly correlation: MERRA2 < ERA5 < HRRR
 - But note that improved model resolution does not solve nighttime representation identified above, especially during the summer

3. Daily errors much smaller than hourly errors

- Daily modeled CF almost always within 20% of recorded value
- So many interesting questions for future research: What drives seasonal variation? How much do low-level jets influence model performance? Do turbulence and atmospheric stability meaningfully influence model performance? What about offshore? ...

Other regions – Region-wide diurnal profiles



Meteorological model:
U, V, at hub-height



Power curve
appropriate for a
plant, with loss
adjustment



Hourly Generation
(MWh)



SUM across all
plants in the region



Region-wide Hourly
Generation (MWh)

?=

Reported generation
for a region



Adjustment for
curtailment




Region-wide Hourly
Generation (MWh)


Diurnal plots notes

- Sum of generation for all plants in a region
 - May not match exact set of plants used by region for their reporting
 - Overall bias may differ from appendix
 - Relative bias (HRRR v. ERA5 v. MERRA2) still interesting
- Main purpose: provide a sense for how well the models represent diurnal cycles in regional wind generation

ERA5 and HRRR more faithfully represent diurnal profiles in the center of the country than MERRA2



HRRR more faithfully represent diurnal profiles in challenging regions than ERA5 or MERRA2



PLUSWIND Data Repository!

- Available to all at DOE's Wind Data Hub



- <https://a2e.energy.gov/project/pluswind>

- Wind speed profiles and generation estimates

- Hourly, 2018 – 2021
 - ~1200 U.S. plants
 - HRRR, ERA5, MERRA2
 - Generation based on power curve matching plant average specific power
 - Reported as hourly capacity factor by plant
 - Simple loss assumptions as an option
 - Simple air density adjustment as an option
 - All data stored in simple csv files



The Plant-Level US multi-model WIND and generation (PLUSWIND) data



Conclusions

Plant-level comparisons in ERCOT

- Models performed worse during nighttime, especially summer nighttime
- More finely resolved models performed better overall, but high resolution did not solve summer nighttime issues
- Daily errors much smaller than hourly errors

Regional diurnal cycles

- Across almost all cases, HRRR contained the most faithful representation of average regional diurnal cycles in wind generation – California and northeast – poor performance from MERRA2 and ERA5

PLUSWIND publicly available!

Contact and acknowledgements

Contact: Dev Millstein (dmillstein@lbl.gov)

Thanks to my coauthors!

Michael R. Davidson, UCSD

Seongeun Jeong, Amos Ancell, Ryan Wiser, LBNL

Acknowledgements:

This work was funded by the U.S. Department of Energy's Office of Electricity and Office of Energy Efficiency and Renewable Energy, in particular the Wind Energy Technologies Office. We thank Patrick Gilman, and Gage Reber for supporting this project.

Disclaimer

This document was prepared as an account of work sponsored by the United States Government. While this document is believed to contain correct information, neither the United States Government nor any agency thereof, nor The Regents of the University of California, nor any of their employees, makes any warranty, express or implied, or assumes any legal responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by its trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or The Regents of the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof, or The Regents of the University of California.

Ernest Orlando Lawrence Berkeley National Laboratory is an equal opportunity employer.

Copyright Notice

This manuscript has been authored by an author at Lawrence Berkeley National Laboratory under Contract No. DE-AC02-05CH11231 with the U.S. Department of Energy. The U.S. Government retains, and the publisher, by accepting the article for publication, acknowledges, that the U.S. Government retains a non-exclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this manuscript, or allow others to do so, for U.S. Government purposes


Appendix




Other regions – Long term bias assessment




Compare generation records to generation estimates




MERRA2: Normalized bias 2018 - 2021



ERA5: Normalized bias 2018 - 2021



HRRR: Normalized bias 2018 - 2021



HRRR has the smallest biases

- HRRR:

- ✓ ERCOT, MISO, SPP, PJM, ISO-NE

- ≈ NYISO

- ✗ CAISO

- ERA5:

- ✓ ERCOT

- ≈ MISO, SPP, ISONE, PJM, ISO-NE, NYISO

- ✗ CAISO

- MERRA2:

- ✓ ERCOT, MISO, SPP

- ≈ NYISO, PJM

- ✗ CAISO, ISO-NE, NYISO

