

Distribution Planning with a Feeder-Level Forecast


Ryan Hinkley
Lead Engineer
Distribution Planning and Asset Management - NY

nationalgrid



Overview

1. National Grid's Feeder Level Forecast Overview
2. Included DER Scenarios and Probabilities
3. Distribution Planning's Inputs into the Forecast
4. Forecast Delivery to Distribution Planning
5. Building the Trust of Planners in the Forecast
6. EV Forecast – Scenario Comparison
7. The Switch to Winter Peaking
8. Example Project




National Grid's Feeder Level Forecast - Overview



Bottom-Up and
Top-Down
Approach



Hourly Data
(8760) through
2050



90/10 Weather
Scenario




Base, Low, and
High Scenario for
Each DER

Included DER Scenarios and Probabilities

DER type	Low(L)	Base(B)	High(H)
Energy Efficiency (EE)	15%	80%	5%
Solar (PV)	20%	75%	5%
Electric Vehicles (EV)	20%	70%	10%
Energy Storage (ES)	10%	80%	10%
Electric Heat Pumps (HP)	10%	85%	5%

DER Adoption Scenarios	Probability
Base Case: EE(B) + Solar(B) + EV(B) + ES(B) + HP(B)	28.56%
EE(B)+PV(B)+EV(L)+ES(B)+HP(B)	8.16% ↓
EE(B)+PV(L)+EV(B)+ES(B)+HP(B)	7.62% ↑
EE(L)+PV(B)+EV(B)+ES(B)+HP(B)	5.36% ↓
EE(B)+PV(B)+EV(H)+ES(B)+HP(B)	4.08% ↑
EE(B)+PV(B)+EV(B)+ES(H)+HP(B)	3.57% ↓
EE(B)+PV(B)+EV(B)+ES(L)+HP(B)	3.57% ↑
EE(B)+PV(B)+EV(B)+ES(B)+HP(L)	3.36% ↓
EE(B)+PV(L)+EV(L)+ES(B)+HP(B)	2.18%
EE(B)+PV(L)+EV(L)+ES(B)+HP(B)	2.18%
EE(B)+PV(H)+EV(B)+ES(B)+HP(B)	1.90%
EE(H)+PV(B)+EV(B)+ES(B)+HP(B)	1.79%
EE(B)+PV(B)+EV(B)+ES(B)+HP(H)	1.68%
EE(L)+PV(B)+EV(L)+ES(B)+HP(B)	1.53%
EE(L)+PV(B)+EV(L)+ES(B)+HP(B)	1.53%
EE(L)+PV(L)+EV(B)+ES(B)+HP(B)	1.43%
EE(B)+PV(B)+EV(L)+ES(L)+HP(B)	1.02%
EE(B)+PV(B)+EV(L)+ES(L)+HP(L)	0.96%
EE(B)+PV(B)+EV(L)+ES(B)+HP(L)	0.96%
EE(B)+PV(L)+EV(B)+ES(L)+HP(B)	0.95%
EE(B)+PV(L)+EV(B)+ES(B)+HP(L)	0.90%
EE(B)+PV(L)+EV(B)+ES(B)+HP(L)	0.90%
EE(L)+PV(B)+EV(B)+ES(L)+HP(B)	0.66%
EE(L)+PV(B)+EV(B)+ES(B)+HP(L)	0.63%
EE(B)+PV(B)+EV(H)+ES(H)+HP(B)	0.51%
EE(B)+PV(B)+EV(B)+ES(L)+HP(L)	0.42%

Distribution Planning “Inputs” into the Feeder Level Forecast



Forecast Delivery to Distribution Planning

A Set of Files for Each Feeder

- Hourly Data Until 2050
- Summary Data (Peaks and Minimums)

One Column for Every DER and Scenario


- Example: 3 Columns for EV Scenarios (Base, Low, High)

Portal for Planners to Retrieve the Files

We Simplify for System Wide Analysis


- Single Value for Every Feeder with Chosen Scenarios

EV Forecast – Scenario Comparison (2023 Forecast)



The higher scenario will result in increased criteria violations that are driving an increase to the number and average size of solutions.

The Switch to Winter Peaking



The peak in NY will shift from the summer to the winter due to the electrification of heat.

The peak hours will shift from early evening, to early morning.

Building the Trust of Planners in the Hourly Forecast



2018: Used the Trends

Increasing = Create a Project

Decreasing = Monitor Prior to Creating a Project



2020: Used the Peaks of a Single Forecast

Create projects based on the yearly peak values in the forecast



2022: Used the Peaks of a Multiple Forecasts with Different Scenarios

Utilized different scenarios of the DERs depending on the local and overall probabilities of each scenario



2024: Improve utilization of the Hourly Data in the Forecast

Prioritize and design projects based on the frequency of peaks in the forecast

Example Project – Battery Energy Storage System (BESS)

Three key datapoints from the forecast to size a BESS:

- **Number of violations per year**
- **Length of time the violation occurs**
- **Magnitude of the violations**

A traditional, single-point forecast cannot provide this detail.

Thank You!

Ryan.Hinkley@nationalgrid.com

nationalgrid

