

JUNE 26, 2025

Incorporating Multivariate Weather Hazards into System Planning with Energy Storage

NEAL MANN

Principal Energy Systems Engineer
Argonne National Laboratory

2025 ESIG Forecasting & Markets
Workshop



Argonne National Laboratory is a
U.S. Department of Energy laboratory
managed by UChicago Argonne, LLC.



KEY QUESTION

- How do extreme weather and changing weather patterns affect the deployment potential for energy storage in power system planning?

Commentary

Extreme weather and electricity markets:
Key lessons from the February 2021 Texas crisis

Todd Levin,^{1,*} Audun Botterud,^{1,2} W. Neal Mann,^{1,3}
Jonghwan Kwon,¹ and Zhi Zhou¹

Joule

Joule 6, 1–15, January 19, 2022 © 2021 Elsevier Inc.

<https://doi.org/10.1016/j.joule.2021.12.015>

METHODOLOGY



Argonne National Laboratory is a
U.S. Department of Energy laboratory
managed by UChicago Argonne, LLC.




WORKFLOW TO APPLY WEATHER IMPACTS TO CAPACITY EXPANSION PROBLEMS

Weather Scenarios

High-Frequency & High-Spatial Resolution Synthetic Weather

Analyze and screen possible future weather patterns




- Temperature
- Precipitation
- Wind/solar availability
- Extreme weather events

Weather to Grid Translation

Translation Models

Generate probabilistic grid event scenarios



- Electricity demand
- Wind/solar profile
- Fuel supply constraints
- Grid asset de-rating
- Grid asset outage

Power System Planning

Argonne's Power System Model
A-LEAF


Power system capacity expansion planning and production cost simulations



- Generation/energy storage mix and dispatch
- Transmission expansion and flows
- Energy and reserves prices

ARGONNE'S LARGE SYNTHETIC WEATHER DATASET

- High resolution, 12 km grid
- Scientific transparency: widely published and scientifically peer reviewed modeling and outcomes
- Dynamical downscaling offers improvements over statistical downscaling
 - Physics-based, addresses non-stationarity
 - Produces 60+ unique climate variables
- High- and low-emissions scenarios
- Three-member ensemble of GCMs
- Three decadal timeframes: historical, mid-century, end-of-century
- Over 100 scenario years @ 3-hourly or hourly time steps
- Summary statistics available on the [ClimRR Portal](#)




WEATHER TO GRID DATA PIPELINE

■ Current features

- Load and demand
- Solar PV output
- Wind output
- Thermal generator outage scenarios

■ Work in progress

- Other generator deratings and outages
- Transmission line deratings and outages
- Water availability (hydro)



POWER SYSTEM MODELING WITH A-LEAF

ADVANCED OPTIMIZATION


- System least-cost planning and operations
- Strategic investments
- Sub-hourly dispatch
- Multiday representative periods
- Simultaneous generation and transmission, and storage expansion planning

DETAILED U.S. GRID DATABASE

- Extensive database of 9000+ U.S. generation resources
- Hourly load profiles for 130+ balancing authorities
- User-defined transmission zones at any scale
- 200+ zone county-level Texas system

CLIMATE AND WEATHER DATA

- Future weather years derived from climate models
- Extreme weather events
- Hourly wind and solar availability for current and future scenarios
- Temperature dependent thermal outages



WHOLESALE MARKET DESIGN

- Multi-stage market settlement
- Scarcity pricing mechanisms
- Forward market modeling

POLICIES AND REGULATIONS

- National and local policies and incentives
- Customizable critical material constraints
- Land use restrictions and resource availability

MULTI-SECTOR INTERDEPENDENCY

- Coupling with a global systems model (TIMES)
- Water-energy nexus
- Transportation systems
- Natural gas infrastructure

RELIABILITY AND RESOURCE ADEQUACY ASSESSMENT

- Probabilistic reliability assessment
- Capacity accreditation using ELCC
- System inertia requirements

SUMMARY OF A-LEAF MODEL SETUP AND ASSUMPTIONS

[See Appendix for More Details](#)


| Parameter | Value |
|---|---|
| Planning stages | 2050 |
| Representative chronology | 10 groups of 5 consecutive days |
| Network scope | ERCOT Weather Zones |
| Tax credits | None |
| Policy-based portfolio requirements | None |
| Generator expansion options | NGCC, NGCT, nuclear, solar PV, wind |
| Storage expansion options | Lithium ion (LFP) 100 MW @ 2, 4, 8 hours duration |
| Transmission expansion | None |
| Energy storage minimum investment | Thermal energy storage (TESS), 10 GW |
| Energy storage minimum investment scenarios | 0, 10, 24, 100 hours duration (0 GWh, 100 GWh, 240 GWh, 1 TWh) |
| Weather years | 8 selected for weather extremes |

SELECTING MULTIVARIATE HAZARDOUS WEATHER EVENTS


- **From 20 synthetic weather years, 5-day multivariate hazard indices were calculated**
 - Spatial and daily average (across Texas) for three variables
 - Normalize and calculate geometric mean of three variables → hazard index
 - Calculate rolling 5-day average hazard indices
- **Eight potentially hazardous events were selected**
 - Low temperature, low wind speed, low solar irradiance → four events
 - High temperature, low wind speed, low solar irradiance → four events

EXAMPLE EVENT: LOW TEMPERATURE, LOW GHI, LOW WIND SPEED


2052-02-02 00:00:00+00:00




Air Temperature [°C]




2052-02-02 00:00:00+00:00




Global Horizontal Irradiance [W/m²]



2052-02-02 00:00:00+00:00



Wind Speed [m/s]



COMBINING REPRESENTATIVE PERIOD SELECTION WITH EXTREME EVENTS

- **The ScenRed¹ scenario reduction method was used first**
 - Samples a user-selected number of n-day periods from a year
 - The periods (day groups) are the scenarios
 - Each day group is given a probability (used as weight)
- **ScenRed output was combined with hazardous periods**
 - Hazardous periods were manually added to the ScenRed output
 - Hazardous period weights were adjusted from 1–50%
 - ScenRed weights were reduced proportionally

¹ See <https://gitlab.com/supsi-dacd-isaac/scenred> & <https://doi.org/10.1007/s10107-002-0331-0>



INITIAL RESULTS




U.S. DEPARTMENT OF
ENERGY

Argonne National Laboratory is a
U.S. Department of Energy laboratory
managed by UChicago Argonne, LLC.




NO THERMAL ENERGY STORAGE (TESS), NO EXTREMES




*Data missing;
simulation incomplete

NO TESS, 1% EXTREMES WEIGHT




Note shifts in NGCC and storage


NO TESS, 10% EXTREMES WEIGHT



NO TESS, 50% EXTREMES WEIGHT




NO TESS, TWO EXAMPLE YEARS




*Data missing; simulation incomplete

WITH TESS, 10 GW @ 10 HOUR DURATION




Note shifts in NGCC and storage

WITH TESS, 10 GW @ 24 HOUR DURATION



Little difference between 10, 24, 100 hours

WITH TESS, 10 GW @ 100 HOUR DURATION



Little difference between 10, 24, 100 hours

CONCLUSION



U.S. DEPARTMENT OF
ENERGY

Argonne National Laboratory is a
U.S. Department of Energy laboratory
managed by UChicago Argonne, LLC.

Argonne 
NATIONAL LABORATORY

OBSERVATIONS

- Developed a new workflow to incorporate extreme and hazardous weather events into power system planning
- Including multivariate hazardous weather events did change capacity expansion results
- As TESS duration was increased from 10 to 24 to 100 hours (all 10 GW), there was little change in the new capacity mix
- Heavier weighting of hazardous events had mixed effects on energy storage capacity
 - Typically flat or less energy storage [MW] as weights were increased
 - 2-hour storage made up a larger proportion of total storage capacity [MW] at the expense of 4-hour storage
 - Interaction/competition with NGCC and solar PV
- 8-hour storage was seen in only a few scenarios

FUTURE WORK

- Expand hazard indices to cover all permutations (in progress)
- Calculate hazard indices for events in all regions of the CONUS (in progress)
- Apply entire workflow to the rest of the CONUS (scalable from counties to whole interconnections)
- Include more detailed reliability simulations to verify results (including probabilistic outages)

ACKNOWLEDGEMENTS AND NOTICE

Acknowledgements

- DOE OE Energy Storage Program
- Argonne National Laboratory
- ANL Laboratory Computing Resource Center
- Project team: Audun Botterud, Christine Cao, Jonghwan Kwon, Todd Levin, Neal Mann, Zhi Zhou

Notice

The submitted manuscript has been created by UChicago Argonne, LLC, Operator of Argonne National Laboratory (“Argonne”). Argonne, a U.S. Department of Energy Office of Science laboratory, is operated under Contract No. DE-AC02-06CH11357. The U.S. Government retains for itself, and others acting on its behalf, a paid-up nonexclusive, irrevocable worldwide license in said article to reproduce, prepare derivative works, distribute copies to the public, and perform publicly and display publicly, by or on behalf of the Government. The Department of Energy will provide public access to these results of federally sponsored research in accordance with the DOE Public Access Plan.

<http://energy.gov/downloads/doe-public-access-plan>



THANK YOU!

W. Neal Mann, PhD
Principal Energy Systems Engineer
Argonne National Laboratory
wmann@anl.gov
<https://www.anl.gov/profile/neal-mann>

APPENDIX






Argonne National Laboratory is a
U.S. Department of Energy laboratory
managed by UChicago Argonne, LLC.




A-LEAF LC-GTEP: FLEXIBLY DETAILED TRANSMISSION MODEL

~90,000 US Transmission Lines
in HIFLD Data




Create a simplified synthetic
network with tunable level of
detail




EXPANDED A-LEAF CAPACITY EXPANSION AND PRODUCTION COST MODEL

- ERCOT zonal aggregated transmission network with individual or aggregated generators



A-LEAF LC-GTEP: RESOLUTION AND DETAIL OPTIONS

Increased robustness, increased complexity 

| Category | Key Features | Modeling Options in A-LEAF | | |
|-------------------------------|--------------------------|----------------------------|--------------------------|---|
| Planning | Planning Horizon | static | milestone-years (manual) | |
| | Type of decisions | investment | + retirement | path optimization + transmission expansion |
| Short-term System Operations | Temporal time resolution | hourly | five minute | |
| | Representative days | time slices | one day | day groups full |
| | Scheduling algorithm | economic dispatch (ED) | | unit commitment (UC) |
| Transmission Network Modeling | Geographical Scope | regional | national | |
| | Spatial Resolution | single zone | multi zone | <i>nodal</i> |
| | Transmission constraints | none | inter-zonal | <i>+selected intra-zonal</i> <i>full</i> |
| | Power flow model | none | Network flow | <i>DC</i> |

DETAILED A-LEAF MODEL SETUP AND ASSUMPTIONS

| Parameter | Value | Parameter | Value |
|---|---|--|--|
| Model type | Least-cost generation and storage expansion | Generator expansion options | NGCC, NGCT, nuclear, solar PV, wind |
| Planning stages | 2050 | Generator cost assumptions | ATB 2024, Moderate |
| Representative chronology | 10 groups of 5 consecutive days | Storage expansion options | Lithium ion (LFP) 100 MW @ 2, 4, 8 hours duration |
| Scheduling | Economic dispatch only | Storage cost assumptions | ESGC 2024, Low Price/Fast Learning |
| Investment decisions | Linear | Transmission expansion | None |
| Retirements | Allowed | Energy storage minimum investment | Thermal energy storage (TESS), 10 GW |
| Network area | ERCOT | Energy storage minimum investment scenarios | 10, 24, 100 hours duration (100 GWh, 240 GWh, 1 TWh) |
| Network aggregation | Weather zone | Fuel prices in 2050 (2021 USD) | Coal: \$1.79 NG: \$3.88 Nuclear: \$0.83 |
| Power flow mode | Pipe flow | Weather years | 8 selected for weather extremes |
| Existing generator/storage aggregation | Individual units | | |
| Planning reserve margin | 13% | | |
| Tax credits | None | | |
| Policy-based portfolio requirements | None | | |