IEEE 2800-2022 Overview and Roadmap to Adoption

Andy Hoke, Ph.D., P.E. Principal Engineer Power Systems Engineering Center, NREL August 11, 2022 ESIG/NAGF/NERC/EPRI Generation Interconnection Workshop

Many slides courtesy of IEEE 2800 Officers:

- Jens C. Boemer, WG Chair
- Bob Cummings, Babak Enayati, Ross Guttromson, Mahesh Morjaria, Manish Patel, Chenhui Niu, Vice-chairs
- Diwakar Tewari, Secretary & Treasurer

General information for the interested public - <u>https://sagroups.ieee.org/2800/</u> and <u>https://sagroups.ieee.org/2800-2/</u>

Full IEEE 2800 standard: https://standards.ieee.org/ieee/2800/10453/ or https://ieeexplore.ieee.org/document/9762253

Acknowledgements and disclaimers

General disclaimer:

The views presented in this presentation are the personal views of the individuals presenting it and shall not be considered the official position of the IEEE Standards Association or any of its committees and shall not be considered to be, nor be relied upon as, a formal position of IEEE, in accordance with IEEE Standards Association Standards Board Bylaws 5.2.1.6.

For those working group members whose effort on the standard was partially or fully supported by the U.S. DOE's National Renewable Energy Laboratory, the following statement applies:

This work was supported in part by the National Renewable Energy Laboratory, operated by Alliance for Sustainable Energy, LLC, for the U.S. Department of Energy (DOE) under Contract No. DE-AC36-08GO28308. Funding provided by U.S. Department of Energy Office of Energy Efficiency and Renewable Energy Solar Energy Technologies Office and Wind Energy Technologies Office. The views expressed in the article do not necessarily represent the views of the DOE or the U.S. Government.


Use of an IEEE standard is wholly voluntary

- IEEE SA can provide information and education if an agency or body (i.e., FERC or DOE) requests information on a standard and can also provide a mechanism by which they can obtain copies of standards for review
- IEEE SA does not lobby or solicit action by any agency or government entity
- Agencies/bodies can have independent discussions outside of IEEE SA
- If a body wants to pursue "requiring" IEEE 2800 via rulings or placing the standard on their respective approved lists for use, that is up to them
- If the individual WG Chair or WG members wish to have discussions with FERC, DOE, etc. about such a required use of the standard, they can have that conversation, but they must be clear they are having that conversation as independent individuals and/or on behalf of their respective organizations, and not IEEE/SA

Pace of IBR Interconnections

All major U.S. interconnections are expected to reach peak **instantaneous IBR levels of 75-98%** within the lifetime of IBRs being connected today.

- These plants will need to not just remain online, but contribute to system recovery and reliability.
- IEEE 2800 addresses minimum technical requirements deemed needed from IBRs.



Data from 2021 DOE/NREL Solar Futures Study: https://www.nrel.gov/analysis/solar-futures.html

IBRs: inverter-based resources like wind, solar, storage

Summary of IEEE 2800 Standard

- Harmonizes interconnection requirements for solar, wind, and storage plants connected to transmission and subtransmission
- A consensus-based draft developed by over ~175 Working Group participants from utilities, system operators, transmission planners, & OEMs over 2 years
- Passed the IEEE SA ballot among 466 SA balloters (>94% approval, >90% response rate)
- Published April 22, 2022

Available from IEEE at https://standards.ieee.org/project/2800.html and via IEEExplore: https://ieeexplore.ieee.org/document/9762253/

More Info at https://sagroups.ieee.org/2800/

Status Quo - Solar, Wind & Storage Interconnection Requirements

 Diverse & different requirements across various jurisdictions

... requires more effort and time to address


- Inverter-based resources (IBRs) are different from synchronous generators
 ...higher (and sometimes lower) capability
- Requirements may not be balanced
 ...some too stringent & not taking advantage of new capability

| ForthBC Avista BPA SMUD PG&F Southern California Edison CAISO IID SDG&E HECO | AffeLink Otter Tail Energy Basin EPC Basin EPC WAPA Tri-State G&T Xcel Platte River Colorado Springs Arizona Public Service Sait River Project Tucson Electric GridLiance AEPCO | NPPD LES OPPD Berkshire Hathaway Evergy GRDA AECI | ATC Great River Minn Power ITC Wolverine Dairyland Exelon MISO City Utilities Ameren SPP | Hydro One Hydro-Quebec NIPSCo OVEC FirstEnergy Dayton AEP Duquesne PJM PPLEU Hoosier Wabash Valley Vectren | NB Power ISO New England VELCO Eversource AVANGRID National Grid New York ISO NYPA Central Hudson Con Edison PSE&G |
|---|---|--|--|--|--|
| | | ERCOT Oncor El Paso Electric LS Power LCRA | EKPC LG&E and H MLGW TVA Southern Cooperative PowerSout Entergy Cleco | Dominion E Duke Santee Coo Georgia Tra | ansmission er |


Source: https://www.natf.net/

Approximately 300 Interested Parties and 175+ WG Members






Broad Collaboration & Coordination




- IEEE/PES/EDPG Main Sponsor
- IEEE/PES/EMC & PSRC Joint Sponsors
- HVDC-VSC <u>Subject Matter Experts</u>
- IEEE/PES/Substations Committee SMEs
- IEEE/PES/Analytic Methods for Power Systems (AMPS) SMEs
- NERC Inverter-Based Resources Performance WG SMEs

IEEE 2800 Objective: Filling Gaps in North American Interconnection Standards



When adopted by the appropriate authority (e.g., transmission owners/operators, NERC, FERC, distribution utilities), IEEE standards become mandatory

IEEE Standards Classification



What to expect from IEEE 2800?

Provides Value

- widely-accepted, unified technical minimum requirements for IBRs
- simplifies and speeds-up technical interconnection negotiations
- flexibility for IBR developers and OEMs \rightarrow not an equipment/plant design standard

Specifies

- performance and functional capabilities *but not* utilization, services, or markets
- functional default settings and ranges of available settings
- performance monitoring and model validation
- types of verifications means, but not detailed procedures (→ IEEE P2800.2)

Scope

 All transmission and sub-transmission connected wind, solar, energy storage and HVDC-VSC

What not to expect from IEEE 2800?

Specifications for grid-forming IBRs

 2800 applies to all IBRs (including grid-forming ones), but was designed with conventional grid-following IBRs in mind

Definition of an interconnection process

- This is up to transmission system owners and their stakeholders and regulators
- 2800 may be used as *part* of such a process

Procedures to verify that IBRs comply with requirements

- Procedures are currently being developed in IEEE P2800.2
- 2800 adoption is *not* contingent on P2800.2

Capability versus Utilization

Capability:

"Ability to Perform" – Required by 2800

- Functions
- Ranges of available settings
- Minimum performance specifications



Examples

- Frequency Response
 - Frequency Droop Response
 - Ramp rate limitations





- Ride-Through
 - Voltage ride-through
 - Current injection during ride-through
 - Consecutive voltage ride-through
 - Frequency ride-through
 - ROCOF ride-through
 - Phase angle jump ride-through

Utilization of Capability:


"Delivery of Performance" – Largely outside 2800 scope

- Enable/disable functions
- Functional settings / configured parameters
- Operate accordingly (e.g., maintain headroom, if applicable)

Examples

- Deadband
- o Droop
- Response Time
- o Headroom

IEEE 2800-2022 Technical Minimum Capability Requirements



Voltage And Reactive Power Control Modes

The *IBR plant* shall provide the following mutually exclusive modes of reactive power control functions:


- RPA voltage control mode
- Power factor control mode
- Reactive power set point control mode

RPA voltage control

- Closed-loop automatic voltage control mode to regulate the voltage at the RPA
- Stable response & any oscillations shall be positively damped (> 0.3 damping ratio)
- Capable of reactive power droop to ensure a stable and coordinated response


| Parameter | Performance Target | Notes | |
|---------------|--------------------------------|----------------------------|--|
| Reaction Time | <200 ms | | |
| Maximum Step | As Dequired by TS Operator | range between 1 s and 30 s | |
| Response Time | As Required by TS Operator | | |
| Damping | Damping ratio of 0.3 or better | | |

Primary Frequency Response (PFR) Capability of an IBR at RPA




Similar to IEEE 1547-2018 Requirements

Voltage ride-through capability – Plants with aux. load limitations, i.e., wind plant



Voltage ride-through capability – Plants without aux. load limitations, e.g., solar plant



Note: June 16 NOPR clause 9.7.3 conflicts with 2800 by requiring "real power production at pre-disturbance levels" and "dynamic reactive power to maintain facility's voltage schedule" during voltage ride-through. 2800 allows for either active or reactive power priority and prioritizes dynamic voltage support rather than maintenance of a schedule when in ride-through conditions.

Minimum ride-

through time (s)

(design criteria)

NA

1.0

1800

6.00

3.00

1.20

0.32

0.32

Frequency Ride-Through *Capability*

| f | | Frequency Range (Hz) | % from f _{nom} | Minimum Time (s) Design Criteria | Operation |
|-----------------------|--|-------------------------|----------------------------|---|------------|
| | apability above and to the right of the red border nay be specified by the TS owner as mandatory. | f_{1}, f_{4} | +3, -5 | 299.0 (t ₁) | Mandatory |
| 0 f ₁ | Otherwise, IBR plant may ride-through or may trip . | | +2, -2 | ~ | Continuous |
| f ₂ | Mandatory operation capability Continuous operatior | capability | $\rightarrow t$ | | |
| <i>f</i> ₄ | Mandatory operation capability Capability below and to the right of the blue border may be specified by the TS owner as mandatory. Otherwise, IBR plant may ride-through or may trip. t ₁ <i>t</i> 1 <i>t</i> 2 <i>t</i> 3 <i>t</i> 3 | | | ROCOF ride-through Shall not trip up | |
| ↓ 0.0s | | | | Measured over 0.1 s window | |


Similar to IEEE 1547-2018 Requirements

Modeling Data

- 2800 is an IBR capability & performance standard. Why include modeling data?
 - Some requirements cannot be verified with tests (type, production, commissioning etc.), i.e., voltage/frequency ridethrough requirements
 - Studies (design evaluation) using models and simulations is necessary to verify that plant meets 2800 requirements
- Requirements to provide "verified models" to Transmission Entity ("shall" language)
 - Steady-state power flow, positive-sequence stability dynamic, EMT, short circuit, harmonics etc.
- Recommends details to be included in the model
- Guidance on how to develop "verified models" is not addressed

Note: June 16 NOPR Attachment A to Appendix 1 only requires EMT models "if Transmission Provider performs an electromagnetic transient study as part of the interconnection study." EMT model may be needed for later studies even if not used at interconnection, at which point it may be to late to obtain one.

Anticipated Timeline, and What Comes Next?



IEEE P2800.2 Introduction

- Title: Recommended Practice for Test and Verification Procedures for Inverter-based Resources (IBRs) Interconnecting with Bulk Power Systems
- WG formed January 2022;
- Recruiting participation from P2800 WG, NERC IRPS, and industry in general
 - Especially need those with knowledge of best practices in designing, studying, interconnecting, commissioning, and operating large IBRs
 - Utilities, project developers, consultants, manufacturers, labs, etc
- See meeting slides etc on public website:
 - https://sagroups.ieee.org/2800-2/
- Contact <u>andy.hoke@nrel.gov</u> to get involved

EEE SA STANDARDS



P2800.2

| Submitter Email: andy.hoke@nrel.gov Type of Project: New IEEE Standard Project Request Type: Initiation / New PAR Request Date: 18 Mar 2021 PAR Reproval Date: 21 May 2021 PAR Expiration Date: 31 Dec 2025 PAR Status: Active | |
|--|---|
| 1.1 Project Number: P2800.2 1.2 Type of Document: Recommended Practice 1.3 Life Cycle: Full Use | |
| 2.1 Project Title: Recommended Practice for Test and Verification Procedures for Inverter-based Resources (IBRs) Interconnecting with Bulk Power Systems | |
| 3.1 Working Group: P2800.2 - Test and Verification of BPS-connected Inverter-Based Resources(PE/ EDPG/P2800.2 - T&V of BPS-connected IBRs) 3.1.1 Contact Information for Working Group Chair: Name: Anderson Hoke Email Address: andy.hoke@nrel.gov 3.1.2 Contact Information for Working Group Vice Chair: None 3.2 Society and Committee: IEEE Power and Energy Society/Energy Development & Power Generation(PE/EDPG) 3.2.1 Contact Information for Standards Committee Chair: Name: Robert Thornton-Jones Email Address: rob.tj@brush.eu 3.2.2 Contact Information for Standards Committee Vice Chair: None 3.2.3 Contact Information for Standards Representative: Name: Zhenyu Fan Email Address: zhenyu.fan@gmail.com 3.3 Co-Stds Committee(s): 3.3.1 IEEE Power and Energy Society/Transmission and Distribution (PE/T&D) Contact Information for Standards Representative: Name: Deniva Sabin@ieee.org 3.3.2 IEEE Power and Energy Society/Flectric Machinery (PE/EM) Contact Information for Standards Representative: Name: Innocent Kamwa Email Address: d.sabin@ieee.org 3.3.2 IEEE Power and Energy Society/Flectric Machinery (PE/EM) Contact Information for Standards Representative: Name: Innocent Kamwa Email Address: chasin@ieee.org 3.3.3 IEEE Power and Energy Society/Analytic Methods for Power Systems (PE/AMPS) Contact Information for Standards Representative: Name: Innocent Kamwa Email Address: chris.dent@ed.ac.uk 3.3.3 IEEE Power and Energy Society/Power System Relaying and Control (PE/PSRCC) Contact Information for Standards Representative: | |
| Name: Don Lukach Email Address: dandmlukach92@gmail.com | _ |

4.1 Type of Ballot: Individual

4.2 Expected Date of submission of draft to the IEEE SA for Initial Standards Committee Ballot: Jun 2023

4.3 Projected Completion Date for Submittal to RevCom: Jan 2024

5.1 Approximate number of people expected to be actively involved in the development of this project: 150

5.2 Scope of proposed standard: This document defines recommended practices for test and verification procedures that should be used to confirm plant-level conformance of inverter-based resources (IBRs)

To get involved in IEEE P2800.2:

To join Working Group:

Attend any two meetings and request membership

Next meeting is August 23-25 (via web meeting)!

Join listserv to be notified of WG meetings (next slide)

WG member iMeet site: <u>https://ieee-sa.imeetcentral.com/p2800-2/home</u> Public website: <u>https://sagroups.ieee.org/2800-2/</u>

To get involved in IEEE P2800.2:

- Overall listserv "P2800-2" will be used to communicate meeting dates, agendas, etc.
- Each subgroup and PQ task force now has a listserv sign up to get involved
 - Overall WG listserv: P2800-2
 - Subgroup 1 (overall document): STDS-P2800-2-SG1
 - Subgroup 2 (type tests): STDS-P2800-2-SG2
 - Subgroup 3 (design evaluation): STDS-P2800-2-SG3
 - Subgroup 4 (commissioning and as-built): STDS-P2800-2-SG4
 - Subgroup 5 (post-commissioning): STDS-P2800-2-SG5
 - Power quality task force: STDS-P2800-2-PQTF
- To join a listserv, send an email message to <u>listserv@listserv.ieee.org</u>
 - In first line of email body, write: SUBSCRIBE <list name> <Your Name>
 - For example, "SUBSCRIBE STDS-P2800-2-SG1 Andy Hoke"

Summary

- IEEE 2800 provides detailed consensus-based interconnection requirements for any non-synchronous generation connected above the distribution level
 - Includes basic performance capabilities needed from all transmission-connected IBRs to maintain grid reliability in the fast-approaching high-IBR future
- Adoption of IEEE 2800 can help preserve grid reliability while also smoothing interconnection by standardizing requirements
 - The initial adoption period will certainly take effort from all stakeholders. This is a necessary effort as we transition to a power system with many non-synchronous resources (whether or not we have a national standard)
 - A national standard can reduce effort compared to an alternative where each balancing entity/control area invents its own approach to the high-IBR challenge
- This won't be easy, but it will only get harder the longer we wait

Questions? Want more info?

IEEE 2800

- Jens C Boemer, j.c.boemer@ieee.org
- Diwakar Tewari, <u>diwakar.tewari@leidos.com</u>

Additional information @

https://sagroups.ieee.org/2800

https://sagroups.ieee.org/2800-2

IEEE P2800.2

- Andy Hoke, <u>Andy.Hoke@nrel.gov</u>
- Manish Patel, <u>MPatel@southernco.com</u>