

Minimum System Demand Issues and Impacts of High DPV at AEMO



Subtitle Here





We acknowledge the Traditional Custodians of the land, seas and waters across Australia. We honour the wisdom of Aboriginal and Torres Strait Islander Elders past and present and embrace future generations.

We acknowledge that, wherever we work, we do so on Aboriginal and Torres Strait Islander lands. We pay respect to the world's oldest continuing culture and First Nations peoples' deep and continuing connection to Country, and hope that our work can benefit both people and Country.

'Journey of unity: AEMO's Reconciliation Path' by Lani Balzan

AEMO Group is proud to have launched its first Reconciliation Action Plan in May 2024. 'Journey of unity: AEMO's Reconciliation Path' was created by Wiradjuri artist Lani Balzan to visually narrate our ongoing journey towards reconciliation – a collaborative endeavour that honours First Nations cultures, fosters mutual understanding, and paves the way for a brighter, more inclusive future.

Read our
RAP



About AEMO


- AEMO is a member-based, not-for-profit organisation.
- We are the independent energy market and system operator for the National Electricity Market (NEM) and the WA Wholesale Electricity Market (WEM), and system planner for the NEM.
- We also operate retail and wholesale gas markets across south-eastern Australia and Victoria's gas pipeline grid.



AEMO Services is an independent subsidiary of AEMO, established in 2021 to enable the transparent provision of advisory and energy services to National Electricity Market jurisdictions.



Electricity




Gas



Declared
Wholesale
Gas Market
(DWGM)

Short Term
Trading
Market
(STTM)
and
Gas Supply
Hub (GSH)

How big is Australia?




Redrawn based on map from:
www.boredpanda.com/country-size-compared-to-usa-north-america



Redrawn based on map from:
www.trapptours.com.au/motorcycle-trip-planning-australia

Renewable contributions are increasing rapidly




Potential:
available renewable
generation over a 30-
minute window –
regardless of actual
generation

Contribution:
renewable generation
produced over a
30-minute window

Integrating DER


Significant work programs across AEMO working on integration of DER



Today's presentation will share a “deep dive” into few selected elements from our work in Operations


Managing low demand conditions

Changing energy demand – South Australia




* Until 1 June 2025

Rooftop solar - Victoria



Record percent of underlying demand met by rooftop solar*



* Record as of 25 Apr 2025

Challenges: The evolving power system



What are the immediate
operational risks?

Challenges: The evolving power system



WA DER

Around a similar time, WA started escalating efforts around management of DPV. WA is an island, so needs to be managed entirely locally.



Since 2020



SA: DPV contingency (DPVC)

Managing risk of possible distributed PV (DPV) “shake-off” in SA island in response to a credible fault, contributing to extremely large credible contingency events. Insufficient fast frequency reserves (insecure).

Challenges: The evolving power system



Since 2024

VIC: Minimum system load (MSL)

Managing risk of insufficient demand in VIC+SA during system normal to support minimum load requirements of units necessary for system strength, voltage management & frequency control.

Leads to violation of VIC transient stability export limits (insecure).



Since 2022



QLD: Minimum system load (MSL)


Managing power system security in QLD during island operation or at-risk of island operation. During high DPV periods, there may be periods of insufficient demand to support minimum load requirements of units necessary for system strength, voltage management & frequency control. Leads to violation energy supply-demand balance and FCAS requirements (insecure).

Challenges: The evolving power system

Now


All NEM

Managing risk of insufficient demand in whole NEM in system normal to support minimum load requirements of units necessary for system strength, voltage management & frequency control. Leads to insufficient system services online (insecure).




“Minimum System Load” (MSL) levels

- MSL framework is modelled after the Lack of Reserve (LOR) framework.
- The LOR framework ensures there is sufficient generation. It is based upon the potential loss of the two largest sources of electricity.
- The MSL framework ensures there is sufficient demand. It manages the potential loss of the two largest loads (includes interconnectors).
- AEMO provides MSL notices to the market and works with the industry to clear them.



MSL1 – Regional demand is two credible load contingencies away from MSL3.

Market notice published for information.



MSL2 – Regional demand is one credible load contingency away from MSL3.

Take actions to land satisfactory following contingency and resecure in 30 mins.




MSL3 – Need to increase regional demand for system security.

Direct NSPs to maintain demand above threshold.

What can we do if demand is below the MSL threshold?

Emergency Backstop includes:

- Curtailing embedded non-scheduled generation
- Direct DPV curtailment (via Smarter Homes Scheme, Relevant Agents, GSDs, Flexible Exports, CSIP-AUS)
- Hot water shifting
- Enhanced Voltage management
- Shedding of reverse flowing feeders



RERT refers to the Reliability and Emergency Reserve Trader, an NER mechanism for AEMO to contract capacity electricity reserves when a reserve shortfall is projected up to nine months in advance.

Procedure summary



0700-0900 (forecast demand < MSL2): BESS to discharge
0900-1300: BESS held in reserve at minimum state of charge

90 mins before MSL3 condition
forecast: Instruction to NSPs to maintain demand above MSL3 threshold. Market Notice.

MSL condition cancelled


Demand < MSL3: NSP actions to maintain demand above MSL3 threshold (best endeavours)

Demand forecast < MSL2: Actions to clear MSL2/3 condition:

- Market notice
- Liaise with TNSPs
- Recall planned outages that reduce region export capability
- Constrain significant non-scheduled generation 0 MW
- Constrain scheduled/semi-scheduled units to 0 MW if not required

Demand forecast < MSL1:

- Market notice




- VIC Forecast demand (latest forecast)
- VIC Actual demand
- - - MSL3 threshold
- ... VIC Forecast demand (1130hrs run)
- VIC Forecast demand (1900 run)


AEMO (Nov 2024) Victorian Minimum System Load Procedure Overview, https://aemo.com.au/-/media/files/electricity/nem/security_and_reliability/power_system_ops/2024-11-01-vic-msl-procedure-factsheet_final.pdf?la=en

Emergency backstop

- November 2024: AEMO released report highlighting urgent need for work to implement emergency backstop capabilities in all NEM mainland regions
- Emergency backstop refers to operational measures to reduce aggregate distributed PV generation if required for system security, when other options have been exhausted.



Minimum demand in the NEM





DPV Contingencies

Distributed PV “Shake-off”

- DPV disconnections by distance from fault location in South Australia

3 March 2017, series of faults in ElectraNet’s Torrens Island 275kV switchyard



Numbers on map display minimum single phase voltage reached during disturbance recorded in the transmission network


Australian Standard AS/NZS4777.2 is the performance standard for grid-connected DER inverters across Australia



Incident analysis:
observed shake-off

AS/NZS4777.2020
published (improved
ride-through
requirements)

AS/NZS4777.2020
becomes mandatory



AS4777 compliance
significantly improved

2018

2019

2020

2021

2022

2023

2024

2025

DER shake-
off risks



DER behaviours
Capstone report



Power system
incidents: still
observing
considerable
shake-off from
new installations


AS4777 compliance
is <50%



Estimates of compliance




- Compliance to AS/NZS4777.2:2020 grid code




Compliance rates of new installations to 2020 standard

- Improvement between early 2022 and Q1/Q2 2024




Estimated visibility of compliance




- Q1/Q2 2024 inverter installations, provided by OEM datasets
- Data has improved in quality since 2023

Behaviour of larger DPV

- 30-100kW systems compared with <30kW systems in recent power system events





Ride-through capabilities of installed PV fleet (up to 5 MW)



DPVC management remains a concern in South Australia, but hopefully will not be a significant contributor to frequency management risks in other regions


Incident analysis



Distributed photovoltaic management during SA island operation



South Australia operational demand and distributed photovoltaic generation on 15 February 2024




- Due to transmission damage on 13 Feb, SA operated at credible risk of separation until 15 Feb.
- On 15 Feb, a DPVC3 (Distributed PV contingency) condition arise, with forecasts of constraint violations on the interconnector.
- The only available action to maintain system security was to reduce distributed PV generation in SA.
- 51 MW of DPV was curtailed (46 MW of larger distributed PV via SCADA control, and 5 MW of small-scale distributed PV curtailed via the Common Smart Inverter Profile – Australia (CSIP-AUS) under the Smarter Homes framework

Distributed PV curtailment



DPV curtailment via flexible export limits (FELs):


Types of responses to curtailment signal on 15 February 2024



- SAPN estimates approximately 16 MW installed capacity of distributed PV was eligible for the FELs mechanism.
- Based on AEMO analysis of smart meter data as well as data provided by SAPN, this 16 MW of capacity is estimated to generate a total of 11.1 MW, of which:
 - 2.2 MW of this generation is self-consumed at the customer site, and
 - The remaining 8.9 MW exported into the grid.
 - ~5 MW of demand increase was successfully delivered via reduction in distributed PV export.

Power system models




Models for DPV and load




Importance of accurate models for DPV and load




Contributions to
incident reporting (DER
behaviours)



Commercial load parameters



V1 Load & DPV models
released for PSS®E



Load & DPV models
released for PSCAD™



2018

2019

2020

2021


2022

2023

2024

2025

First prototype
models



DER behaviours
compilation




Application of models to
calculating security limits

Load & DPV models
updated for PSS®E



OLD
(1999)


STATIC
MODEL




$$P = P_0 v (1 + 0.5 \times \Delta f)$$
$$Q = Q_0 v^3$$

NEW
(2022)



DYNAMIC
MODEL






Distributed PV (DPV) Model




Load & Distributed PV Shake off



AEMO (Nov 2022) PSSE models for load and distributed PV in the NEM, <https://aemo.com.au/-/media/files/initiatives/der/2022/psse-models-for-load-and-distributed-pv-in-the-nem.pdf?la=en>





Excellent improvement in trajectory of reactive power (compared with exponential model)



Tend to underestimate post-fault clearance overshoot on active power (but captures general trend at least as well as exponential model)

Captures observed steady-state load
disconnection reasonably well (and
significant improvement over
exponential model)


Large swings – is this real?



27 March 2024 – Event Summary



275 kV current transformer failures in South Australia



Pre-fault Conditions	
Operational demand	589 MW
Underlying demand	1887 MW
DPV generation	1298 MW










Estimated Change	
Operational demand	68 MW increase (12%)
Underlying demand	75 MW decrease (4%)
DPV generation	143 MW decrease (11%)

Radial HSM: 11 kV North Unley, SA



SINGLE LINE DIAGRAM




TRANSIENT RESPONSE

STEADY STATE RESPONSE

North Unley Zone Substation

Pre-fault Conditions

Operational demand	2.4 MW
Underlying demand	7 MW
DPV generation	4.6 MW




Operational Demand Swings Observed


11 kV North Unley Feeder




Active power measurements & model outcomes



Individual model outcomes: change in active power (MW)



Influence of DPV levels on OD swings




- OD swings are consistently observed
- The size of the swing appears to be strongly affected by
 - DPV penetration level
 - depth of the voltage depression

Simulation outcomes



- 27 March event with more severe credible fault, and increasing DPV penetration



When aggregated across a whole region, this behaviour can lead to a significant transient (~200ms duration) increase in regional operational demand post fault.




Uplift of operational systems


Uplift of operational systems to integrate DER


- Mapping of existing systems, identifying those most impacted by DER, prioritisation for uplift
- High priority initial focus areas:
 - Control room visibility tools for managing Minimum System Load (MSL)
 - Tools for calculating MSL thresholds
 - Incident analysis tools – Automating triggering & handling large complex datasets
 - Distributed PV into Energy Management System in correct locations, with automated updates
 - Integrate DER models into AEMO Modelling Platform for robust ease of use

For more information:

ACCESS MARKET PORTALS ▾

CALENDAR  CAREERS CONTACT  MARKET NOTICES  SUBSCRIBE 

AEMO

Energy systems Initiatives Consultations Library Learn Newsroom About 

AEMO • INITIATIVES • MAJOR PROGRAMS • DISTRIBUTED ENERGY RESOURCES PROGRAM • MANAGING DISTRIBUTED ENERGY RESOURCES IN OPERATIONS

← Distributed Energy Resources Program

About the DER Program >

Markets and Framework +

DER Demonstrations +

Managing Distributed Energy Resources in Operations -

DER behaviour during disturbances

Power system model development

Managing Minimum System Load (MSL)

Adapting and managing Under Frequency Load Shedding at times of low demand

Standards and connections +

Managing Distributed Energy Resources in Operations

The Operations workstream addresses the operational impacts of increasing levels of DER penetrating the electricity grid.

Its objectives are to ensure the operational systems are in place to maintain energy system security with regards to:

Understanding how distributed resources behave during disturbances →

Developing power system models of DER and load behaviour →

Managing Minimum System Load →

Adapting Under Frequency Load Shedding at times of low demand →

Findings and references in each area are summarised in the relevant sub-page.

- <https://aemo.com.au/initiatives/major-programs/nem-distributed-energy-resources-der-program/managing-distributed-energy-resources-in-operations>

46



For more information visit
demo.com.au