

#### MISO Interconnection Queue Overview – Storage, Hybrid Resources

Workshop on Battery Storage, Hybrid Resources, Frequency Response and Grid Services September 17, 2019

#### **Generator Interconnection: Overview**

The current generator interconnection active queue consists of 625 projects totaling 98.6 GW







#### Historic trends indicate growth in development of renewable energy

Chart values per MISO's interconnection queue database (by date processed into the queue)



## Storage in MISO



MISO

### What is a Hybrid Interconnection?

A Generating Facility that utilizes more than one fuel source to inject power on to the Transmission System





## **Hybrid Interconnections**



MISO

# Modeling of Storage in MISO

#### **Generator Interconnection Studies**

- Interconnection Studies model Energy Storage as positive and negative generators
- Study at +/-100% output in both summer peak and shoulder peak study models
- Modeling assumptions are discussed at MISO stakeholder forums (PSC)

#### Long-term Planning (MTEP)

 Storage with Interconnection Service will be dispatched up to its NR (Network Resource) level based on the economics in the base dispatch





## **Generator Interconnection Dispatch**

Fuel Type	Summer Peak Dispatched as % of Interconnection Service	Shoulder Peak Dispatched as % of Interconnection Service				
Combined Cycle	100%	50%				
Combustion Turbine	100%	0%				
Diesel Engines	100%	0%				
Hydro	100%	100%				
Nuclear	100%	100%				
Steam – Coal	100%	100%				
Oil	100%	0%				
Waste Heat	100%	100%				
Wind	15.6%	100%				
Solar	100%	50%				
Battery	+/- 100%	+/- 100%				



## Hybrid Interconnection Dispatch

Scenario Wind Solar		ğ	ode	Steady State			Steady State				NRIS or Deliverability						
	age	/s iste	Ĕ	(Shoulder Peak)			(Summer Peak)			(Summer Peak)							
	Sol	Stora	MM Reque	Storage	Wind	Solar	Storage	Hybrid Output	Wind	Solar	Storage	Hybrid Output	Wind	Solar	Storage	Hybrid Output	
1	100	100 50	0	120	Discharging	96	24	0	120	15.6	50	0	65.6	80	40	0	120
			Charging	N/A													
2	2 100 50 0	0	150	Discharging	100	50	0	150	15.6	50	0	65.6	100	50	0	150	
				Charging	N/A												
3	3 100 0 5	50	50 120	Discharging	80	0	40	120	15.6	0	50	65.6	80	0	40	120	
				Charging	0	0	-50	-50	0	0	-50	-50	N/A				
4	100 0 5	50	150	Discharging	100	0	50	150	15.6	0	50	65.6	100	0	50	150	
			Charging	0	0	-50	-50	0	0	-50	-50	N/A					
5	5 0 100	50 120	120	Discharging	0	50	50	100	0	80	40	120	0	80	40	120	
				Charging	0	0	-50	-50	0	0	-50	-50	N/A				
6 0 100	50 150	150	Discharging	0	50	50	100	0	100	50	150	0	100	50	150		
			Charging	0	0	-50	-50	0	0	-50	-50	N/A					



# Study Practices for Storage – Charging

#### □ Energy storage requests that are expected to charge from MISO Grid:

 Storage requests will be studied as "negative generation" in both summer peak and shoulder peak scenarios at full output in the DPP studies

#### □ Storage devices :

- are considered as a generation asset if they are requested through the GI queue; NERC TPL 001-4 standard will be applied as if the storage device is a generator and not a load,
- have the capability to make offers for charge and discharge in the markets similar to other generators, and
- will be responsible for Network Upgrades coming out of GI studies, where the GI study criteria can be applied consistently if they are studied as negative generation in DPP studies.



# Study Practices for Storage – Charging

- Storage devices are required to have Transmission Service to withdraw energy from the Grid
- Obtaining a GIA does not grant Transmission Service
- □ IC can either:
  - be an independent Load Serving Entity (LSE) and Market Participant (MP), and directly request for new transmission service (NITS or Point to Point) from MISO, or
  - work with another existing MP/LSE service to obtain transmission service



#### **Distribution-connected Interconnections**

- Coordination is required for interconnection requests with facilities connecting to distribution system (non-MISO)
- If MISO and the affected TO believe there is potential for reliability issues, parties will engage the interconnection customer and perform a system impact study and if upgrades are needed a facility study



## **MISO References**

- MISO Website
  - <u>www.misoenergy.org</u>
- MISO Generation Interconnection
  - <u>https://www.misoenergy.org/planning/generator-interconnection/</u>
- Interconnection Process Working Group
  - <u>https://www.misoenergy.org/stakeholder-</u>
    <u>engagement/committees/interconnection-process-working-group/</u>



# Questions?

Cody Doll

Principal Resource Utilization Engineer (651) 632-8575

cdoll@misoenergy.org



