



# MISO's Review of Interconnection Requirements

Potential opportunities from reviewing standard IEEE  
2800 capabilities and performance requirements

# Starting at the larger reliability picture, Today MISO will share how IEEE 2800 implementation and generator requirements fit in

1. MISO's System Reliability **Attributes** effort in relation to Inverter-Based Resources (IBR)
2. Comparing **current generator interconnection requirements** against Standard IEEE 2800
3. **Opportunities to incorporate IEEE 2800 IBR** capability and performance requirements

# MISO recently initiated an investigation into needed System Attributes and how the continued resource transition could alter Attribute availability in the coming years

## ISSUE

The resource transition continues to accelerate in the MISO region, creating new risks to reliability and market efficiency.


## IMPLICATIONS

New resources do not have the same characteristics as those they are replacing, leading to the potential scarcity of attributes needed to operate the system.

## HYPOTHESIS

We need to understand attributes necessary to provide ongoing system reliability and identify / implement methodologies (e.g., visibility, requirements, or market products) that will ensure those attributes are available.


# MISO's initial focus is on understanding the timing and scale of needed Reliability Attributes along with the risks posed, should certain Attributes become scarce



# While energy and capacity are given significant attention, many critical attributes are required for reliable operations



- Availability



- Fuel assurance
- Long duration energy at high output



- **Voltage stability**
- **Small signal stability**
- **Voltage control**
- **Black start**
- **Detection of short circuit fault**
- Regulation
- Contingency reserve

Potential positive contributions from standard Inverter-Based Resource capabilities



- Ramp up capability
- Ramp down capability
- Short minimum down time
- Short minimum run time
- Rapid start-up

# MISO kicked off an IEEE 2800 adoption effort in support of the Reliability Imperative and evolving system Attribute needs

**Objective:** Leverage recent industry developments surrounding inverter-based resource performance needs and capabilities, namely the publication of IEEE 2800-2022, with an aim to mitigate undesirable reliability events outlined in recent NERC disturbance reports and to position MISO for beneficial use of other IBR attributes (e.g., fast frequency response).

- By defining standard minimum performance requirements, MISO is benefiting from industry standardization and lessons-learned in other jurisdictions.
- Most performance issues identified by recent NERC disturbance reports could be remedied by IEEE 2800 compliance.

# MISO performed outreach to peers and industry experts to capture a wide range of perspectives

## Peer ISOs/RTOs

- Experienced significant IBR reliability events starting ~ 5 years ago with larger events serving as “wake up call”.
- IEEE 2800 covers capabilities to address IBR reliability issues but is ineffective without enforceable compliance steps.
- IEEE 2800 can drive consistent plant performance and simplify some technical challenges
- Clause-by-clause adoption or recreation of standard concepts in requirements
- May go above and beyond IEEE 2800 requirements for some functions (e.g., phase angle jump)

## Transmission Owners

- Adopting parts of IEEE 2800 through Local Planning Criteria update (e.g., dynamic active and reactive power responses).
- This TO’s 2800 adoption is coupled with EMT modeling requirements with model verification being a major component of the effort.

## Industry Standards Experts


- While a wholesale NERC adoption of IEEE 2800 is not anticipated, ISO/RTO and TO adoption is highly encouraged based needs outlined in NERC Disturbance Reports and Reliability Guidelines<sup>1</sup>.
- Echoing ISOs/RTOs with events, standard compliance along with model verification and validation are most pressing future issues.

[1] NERC, Reliability Guideline, Improvements to Interconnection Requirements for BPS-Connected Inverter-Based Resources, September 2019. Available at: [https://www.nerc.com/comm/RSTC\\_Reliability\\_Guidelines/Reliability\\_Guideline\\_IBR\\_Interconnection\\_Requirements\\_Improvements.pdf](https://www.nerc.com/comm/RSTC_Reliability_Guidelines/Reliability_Guideline_IBR_Interconnection_Requirements_Improvements.pdf)

# In the past, MISO has updated interconnection requirements as industry best practices emerge

In 2020, prompted by new NERC Guidelines, MISO updated generator requirements:


- **Momentary cessation** prohibited
- **Phase jump** immunity introduced
- **Monitoring** and recording events to 1ms resolution
- **Rate-of-change-of frequency** protection prohibited except for equipment protection



Given MISO's current interconnection queue, with roughly 95% of new applications being IBR, and the release of IEE 2800, the timing is right to revisit interconnection requirements.<sup>1</sup>



# The team has followed a gaps analysis approach to focus potential recommendations



- Step 2**
- Recommend implementation priority and timing for gaps, based on factors that may include:
- MISO reliability need
  - Stakeholder perspectives
  - OEM readiness
  - Test and verification feasibility
  - Tariff implications
- MISO’s approach was inspired by the work pioneered by EPRI and ERCOT.<sup>1</sup>

9 [1] ERCOT, IEEE 2800 vs Existing ERCOT Interconnection Requirements, Gaps Analysis Learnings. August 11, 2021.

# Preliminary potential opportunities to refine interconnection requirements were identified for further investigation and stakeholder discussion

- Range of available settings
  - Measurement accuracy
  - Prioritization of functions
  - Ramping for control parameter change
  - Responding to external control inputs
  - Voltage control - specific control parameters and remote control
- Constant reactive power
- Reactive power capability at zero active power
- Current injection through voltage ride-through – balanced and unbalanced
- ROCOF ride-through
- Transient overvoltage ride-through
- Consecutive voltage deviation ride-through
- Restore output after voltage ride-through
- Fast frequency response – over frequency and under frequency
  - Remote configurability

Note: MISO gaps/opportunities vary in nature from unspecified capabilities to refinements in already required capabilities or functional performance settings

## In early 2023, MISO plans to gather stakeholder input on IBR requirement prioritization, implications, and timing


- MISO intends to share the opportunities identified through the stakeholder Interconnection Process Working Group.
- Stakeholder feedback will help inform MISO's IEEE 2800 implementation plan.
- Implementation will likely require MISO Tariff changes to the pro forma Generator Interconnection Agreement



# Questions?

Patrick Dalton  
[pdalton@misoenergy.org](mailto:pdalton@misoenergy.org)

# MISO's 2022 Generator Interconnection Queue Submissions Set New Records for MISO both by Volume and Makeup



Fuel	# of Requests	GW
Solar	469	83.7
Storage	231	32.3
Hybrid	163	34.3
Wind	66	13.9
Natural Gas	21	5.0
Other	6	1.6
<b>Grand Total</b>	<b>956</b>	<b>170.8</b>