

NERC

NORTH AMERICAN ELECTRIC
RELIABILITY CORPORATION

Blue Cut Fire and Canyon 2 Fire Disturbance Analyses

Key Findings and Recommendations


Ryan Quint, Advanced Analytics and Modeling, NERC
UVIG Spring Technical Workshop
March 2018

RELIABILITY | ACCOUNTABILITY





August 16, 2016
Blue Cut Fire Disturbance

Refresher on Key Findings and Recommendations




- 26 utility-scale (most at 500 kV and 230 kV) solar developments
- 10 different inverter manufacturers

- Largest solar PV loss (~700 MW) due to underfrequency tripping
 - Inverter sensed near instantaneous frequency of **< 57 Hz** and tripped



- Inverters have three modes of operation:
 - **Continuous Operation:** injecting current into the grid
 - **Trip:** cease injecting current, disconnect from grid, wait ~5 mins, automatically return to service if voltage and frequency within bounds
 - **Momentary Cessation:** momentarily cease injecting current during voltages outside continuous operating range – 0.9 to 1.0 pu)



| Susceptible to Erroneous Frequency Calculations? | | | |
|--|---------------|------------|----------------|
| | MW | Responses | Inverter units |
| Yes | 6,244 | 74 | 7,148 |
| No | 10,527 | 76 | 7,230 |
| Total | 16,771 | 150 | 14,378 |




Figure 2: MW susceptible to Erroneous Frequency Calculations

| Inverter cease output during abnormal voltages? | | | |
|---|---------------|------------|----------------|
| | MW | Responses | Inverter units |
| Yes | 14,113 | 119 | 11,821 |
| No | 2,657 | 31 | 2,557 |
| Total | 16,771 | 150 | 14,378 |





Figure 4: MW cease output during abnormal voltages

October 9, 2017
Canyon 2 Fire Disturbance


Key Findings and Recommendations




*Smoke-induced L-L fault events caused by Canyon 2 Fire...
Both fault cleared normally...*




Fault Event 1:
220 kV
L-L Fault
< 3 cycle clearing



Fault Event 2:
500 kV
L-L Fault
< 3 cycle clearing






1. No erroneous frequency tripping
2. Continued use of momentary cessation
3. Ramp rate interactions with return from momentary cessation
4. Interpretation of PRC-024-2 voltage ride-through curve
5. Instantaneous voltage tripping and measurement filtering
6. Phase lock loop synchronization issues
7. DC reverse current tripping
8. Transient interactions and ride-through considerations

No erroneous frequency tripping


- Alert recommended GOPs and GOs ensure inverter controls do not erroneously trip on instantaneous frequency measurements
- By October 9, 2017 event, 97% of inverter manufacturer's BPS-connected fleet had been updated
- Mitigating actions by inverter manufacturer and GOs appear to have worked

Continued use of momentary cessation

- Most inverters use momentary cessation ($V < 0.9$ pu)
- Recovery of current following momentary cessation varies, relatively slow for grid dynamics
- Blue Cut Fire recommendation – interim solution
- NERC IRPTF studies – new recommendation




Clarification and Recommendation for Momentary Cessation




Clarification and Recommendation for Momentary Cessation

$t_{\text{fault}} + 0.5 \text{ sec}$




Clarification and Recommendation for Momentary Cessation

$t_{fault} + 1.0 \text{ sec}$




Clarification and Recommendation for Momentary Cessation




Clarification and Recommendation for Momentary Cessation

$t_{\text{fault}} + 2.0 \text{ sec}$




Clarification and Recommendation for Momentary Cessation

$t_{\text{fault}} + 2.8 \text{ sec}$




- Generator Owners should coordinate with their inverter manufacturer(s) to **eliminate momentary cessation (MC) to the greatest extent possible**.
- For inverters where MC cannot be eliminated (e.g., use another form of ride-through mode), MC settings should be changed by:
 - Reducing the MC low voltage threshold to the lowest value possible.
 - Reducing the recovery delay to the smallest value possible (e.g., on the order of 1-3 electrical cycles).
 - Increasing the active power ramp rate to at least 100% per second (e.g., return to pre-disturbance active current injection within 1 second).
 - Setting reactive current priority upon recovery (if applicable) should eliminate the use of MC on all inverters that are capable of continuous current injection during abnormal voltages.

Interpretation of PRC-024-2 voltage ride-through curve




Instantaneous voltage tripping and measurement filtering




| Inst. Voltage [pu nominal peak] | Samples | Time [sec] | Cycles |
|---------------------------------|---------|------------|--------|
| > 1.1 | 5 | 0.00167 | 0.1 |
| > 1.2 | 4 | 0.00133 | 0.08 |
| > 1.3 | 4 | 0.00133 | 0.08 |
| > 1.4 | 3 | 0.00100 | 0.06 |

Instantaneous voltage tripping and measurement filtering

| High Voltage Ride Through Duration | | Low Voltage Ride Through Duration | |
|------------------------------------|--------------------|-----------------------------------|------------|
| Voltage (pu) | Time (sec) | Voltage (pu) | Time (sec) |
| ≥ 1.20 | Instantaneous Trip | ≤ 0.45 | 0.15 |
| ≥ 1.175 | 0.20 | ≤ 0.65 | 0.30 |
| ≥ 1.15 | 0.50 | ≤ 0.75 | 2.00 |
| ≥ 1.10 | 1.00 | ≤ 0.90 | 3.00 |



Instantaneous voltage tripping and measurement filtering



- Disturbance Report – published February 21, 2018
- Informational webinar – held February 15, 2018
- NERC Alert – coming likely in March 2018
- Reliability Guideline on Inverter-Based Resources Performance – Q3 or Q4 2018
- Ongoing informational webinars – Q2-Q4 2018
- NERC-NATF-EPRI-UVIG Webinar Series on Inverter-Based Resources – Q2-Q3 2018 (posted on NERC Calendar)
- Technical Workshop – planned for Q3 or Q4 2018

- Blue Cut Fire Disturbance Report:
<http://www.nerc.com/pa/rrm/ea/Pages/1200-MW-Fault-Induced-Solar-Photovoltaic-Resource-Interruption-Disturbance-Report.aspx>
- Canyon 2 Fire Disturbance Report:
<http://www.nerc.com/pa/rrm/ea/Pages/1200-MW-Fault-Induced-Solar-Photovoltaic-Resource-Interruption-Disturbance-Report.aspx>
- Webinar on Both Disturbances:
<http://www.nerc.com/pa/rrm/ea/Pages/1200-MW-Fault-Induced-Solar-Photovoltaic-Resource-Interruption-Disturbance-Report.aspx>
- NERC Events Analysis: <http://www.nerc.com/pa/rrm/ea/Pages/default.aspx>
- NERC Alerts: <http://www.nerc.com/pa/rrm/bpsa/Pages/Alerts.aspx>
- NERC IRPTF Page:
<http://www.nerc.com/comm/PC/Pages/Inverter-Based-Resource-Performance-Task-Force.aspx>



Questions and Answers

Ryan Quint, PhD, PE

Senior Manager, Advanced Analytics and Modeling


North American Electric Reliability Corporation

Office (202) 400-3015

Cell (202) 809-3079


ryan.quint@nerc.net

Ramp rate interactions with return from momentary cessation




Phase lock loop synchronization issues

- Grid voltage phase jumps occur (e.g., during faults)
- Inverter PLLs should be robust to withstand BPS phase jumps
- Should not result in inverter tripping or momentary cessation
- Advanced controls should enable “PLL ride-through” rather than tripping



DC reverse current tripping

- Anti-parallel diodes dissipate energy, mitigate voltage spikes
- Can conduct if forward biased (AC voltage > DC voltage)
- UL 1741 requires testing and detection, no specified trip settings
- DC reverse current detection protects panels, not inverter
- Very sensitive settings for one plant



Transient interactions and ride-through considerations

- Interactions between momentary cessation, in-plant shunt capacitors, transient voltages, harmonics, etc., that are not sufficient understood
- Requires detailed electromagnetic transient (EMT) studies needed

