Advanced Linkages Between Power Flow and Production Cost Modelling



ESIG Tutorial: Integrating Planning Tools and Processes for Effective Planning of Future Power Systems

March 2023 GEEnergyConsulting.com

© 2019 General Electric Company - All rights reserved

DULED MAINTENANCE

GE Energy Consulting



*Trademark of General Electric © 2019 General Electric Company - All rights reserved

GE Energy Consulting: GE's grid experts for >100 years GE EXPERTS, OEM AGNOSTIC

~130 grid experts9 countries>100 patents



GE Energy Consulting models grids **across the globe** 40 COUNTRIES ... 5 CONTINENTS



Economics + Physics

Transmission constrained + least cost dispatch to serve load

High resolution

Hourly in time ... nodal/zonal in space

Forward-looking

20 year forecast ... transmission, generation + historical validation

Top technologies

Leading generation types independent of manufacturer

North America: Canada, US, Mexico • Europe: UK, Ireland, Spain, Portugal, France, Italy, Luxemburg, Belgium, Netherlands, Germany, Poland, Russia, Sweden, Greece, Turkey • South America: Chile, Argentina, Peru, Brazil • Africa: Morocco, Algeria, Tunisia, Egypt, Ghana, Nigeria • Middle East: Saudi Arabia, Bahrain, Qatar, UAE, Oman, Kuwait, Iraq, Israel • Asia: India, Bangladesh, Pakistan, Myanmar, Thailand, Vietnam, Laos, Cambodia, Philippines, Malaysia, Singapore, Indonesia, Brunei, Taiwan, Japan, S. Korea



Driving insightful client decisions: costs -> revenues, planning -> operations

Increasing Complexity of Grid Modelling



*Trademark of General Electric © 2019 General Electric Company - All rights reserved

Deep decarbonization ... Holistic planning required Hourly analysis to identify new periods of risk ID new periods of risk:



Are there risks to gas supply as we decarbonize?

Cross-sector insight required

to identify reliability needs



ark of General Electric Ref: EIA STEO 2020, AEO 2020 outlook, GPCM, MAPS a registered trademark of RBAC, Inc.

Even at ~20% average wind + solar, California sees hours at 80%! New non-peak hours of risk



© 2023 General Electric Company - All rights reserved

Grid reliability is maintained across multiple timescales

Planning tools reflect similar timescales

PHYSICS ... maintain frequency & voltage



... deliver enough power to meet demand



<	– SECONDS –	- HOURS	– YEARS –––––	\rightarrow

https://www.nerc.com/pa/rrm/ea/Pages/Major-Event-Reports.aspx

https://www.aer.gov.au/wholesale-markets/compliance-reporting/investigation-report-into-south-australias-2016-state-wide-blackout

	NETWORK RISKS ASSESSMENT			NEEDS		IMPLEMENTATION					
			LOAD FLOW	DYNAMICS	TRANSIENTS	OTHER		DISPATCH DEPENDENT	MECHANISM	GEN SYNCHRONOUS	ERATION INVERTER
ISKS		STEADY STATE Normal and outages	\checkmark				Transmission adequacy	\checkmark	Network upgrades	Shifting mix influen of power flows a	ces direction and timing nd thermal limit risks
RK R	0 1	FREQUENCY STABILITY Steady state and disturbances	< €} <	\sim			Inertia and fast frequency response	×	Grid codes Ancillary services	Inherent to machine	Via converter controls
>							Primary response (governor)	\checkmark	Grid codes	No opportunity cost	Pre-curtailment req'd. non-zero cost
ETV ignal dis		VOLTAGE STABILITY		→ √ *	\rightarrow		Voltage control	×	Grid codes Interconnect	Via excitation &	Via converter
Ζ	ר אר א קר אר א של אר א	Steady state and disturbances				Reactive power	×	approval	rotational physics	controis	
DN		WEAK GRID Control stability		~ €	₹ √ €	Short circuit analysis	Voltage source	×	Grid codes Interconnect approval	Via short circuit current	Via grid-forming controls
EVALUAT Small signal	811a1	TRANSIENT STABILITY Angular stability rotor and system		✓ _	• •		Transmission adequacy	\checkmark	Network upgrades	Critical clearing time	Phase-locked loop (traditional)
	Small si	SMALL SIGNAL STABILITY				Frequency domain	Power swing damping	\checkmark	Grid codes	Power system stabilizer (PSS)	Power oscillation damping
		sub synchronous resonance (SSR)			v	and Bode analysis	SSR damping	\checkmark	Interconnect approval	TSR (SSR/SSTI)	Active damping controls for (SSR/SSCI)



Three main flavors of grid stability assessment *e.g. New project interconnection study*

Violations can result in upgrade costs, denied interconnection, curtailment

TRANSIENTS



DYNAMICS

SOFTWARE

LOAD FLOWS

Siemens PSS/e*, GE PSLF, Digsilent Power factory PSCAD*, windTRAP, ATP ⁻ EMTP-RV

GE MAPS* Production Cost Modelling



*Trademark of General Electric © 2019 General Electric Company - All rights reserved

GE MAPS*: An **iterative + integrated** approach to energy market simulation



Static inputs

Fuel price Market view



GE MAPS* database: Generators

ITERATIVE APPROACH ... BUILD/RETIRE TO MEET RESERVE MARGINS & UNIT PROFITABILITY





GE MAPS* database: Gas price forecast PLANT-LEVEL PRICES VIA ELECTRICITY + GAS MARKET MODELING







* Trademark of General Electric **GPCM is a registered trademark of RBAC, Inc.

© 2023 General Electric Company - All rights reserved

GE MAPS* database: Coal & oil price forecast

Coal price forecast ... price elastic





GE MAPS* database: Transmission model TRANSMISSION CAN HAVE A SIGNIFICANT INFLUENCE ON PRICE





GE MAPS* database: **Transmission model** BRINGING PHYSICS INTO FINANCIAL MODELING



The electrical network

The ideal grid: how the circuit directs power



RTO-sourced: annual update, CEII access req'd **Four main elements:** gen, loads, nodes, lines ... GE PSLF* model **Specs:** Node #'s, MW ratings, impedances

Operational constraints

The real grid: reliability rules/exceptions



3) Operational exceptions

GE intel: decades of RTO research, NDAs req'd

- **1) Contingencies:** grid balance w/ outages (N-1)
- 2) Interface limits across multiple lines (MW & V)
- **3) Operational exceptions:** Must-run units, underground line exceptions, local req'ts



4

Round Trip modelling

Round-Trip Modeling

A common round-trip model is to feed the generation dispatch from a production cost model into a power flow (PSSE or PSLF) model.

- ✓ Why go through this process?
- ✓ Why not just run each model separately?

Typically, the PSSE or PSLF model is of a max or min load case. These cases are estimates of generation levels to match a max and min load event. However, the generation is not based on an economic dispatch.

 Using the production cost model to effectively dispatch generation, and to be able to choose the right time period to be represented in the power flow (other than a min or max load case), like high renewables case, is often more relevant for most studies.

Another reason for round trip modelling, is to align the models to the same assumptions or starting point. For example a production cost and reliability study may require aligning the models assumptions before starting the study.

Inter-model setup

The key to most model inputs and outputs is having a consistent database, particularly generators.

Using the same generator naming convention is ideal.

✓ This can often be difficult or non-existent for established databases where the names are already established.

The next best thing is having a unique generator identifier, like EIA generator number, for both datasets. Other alternatives (particularly for overseas models) is PLATTS UDI generator number.

✓ Then the inputs and outputs can be lined up without too much trouble.

Some software allow imports / exports from other products.

✓ PLEXOS has an import feature of PSSE load flow cases for example. The naming convention will default to the parent database (e.g. PSSE).





have been want to be k both models outputs or other as well arty dataset

Benchmarking example above of ERCOT between production cost models GE MAPS and PLEXOS for 2022.

- ✓ Benchmarking will help validate the accuracy of the models.
- Benchmarking can be done relative to historical data or a back-cast where a model is run for a historical year and compared to historical results (LMP, generation, or other relevant metrics).



Sharing of Results

Ideally, the best way to share results between models would be to have a common output file like a .csv file or similar that could then be used as an input into the subsequent step of modelling.

Alternatively, build a template from which one could wholesale copy the results from one model and paste into the second.

- ✓ Sometimes this require a bit of trial and error and is initially a manual process.
- ✓ However, if this is likely to be a common approach, then would be beneficial for ways to automate the exchange of data with the use of python or an API.
- ✓ For example, ECG has built a script to take regular updates from our North American GE MAPS* databases and automatically update inputs into our PLEXOS database (for capacity expansion or specific studies requiring that software).



Case Study



Value and Role of Pumped Storage Hydropower under High Variable Renewables

Chrissy Bisceglia Senior Engineer GE Energy Consulting

2021 General Electric Company, Proprietary. All Rights Reserved.

VALUATION OBJECTIVES

EVALUATE AND UNLOCK FULL POTENTIAL OF PSH TO SUPPORT GRID OPERATIONS, STABILITY & RESILIENCY

Overcome market barriers and enable PSH technology deployment for utilities, Public Utility Commissions (PUCs), developers and regional planners

- Develop a **PSH scheduling tool** to co-optimize energy and ancillary services, considering price elasticity in the power market
- Analyze and quantify the **potential value of PSH** under different system conditions
- Develop a set of Variable Speed PSH stability models for transmission planners to study the impact of PSH on the grid
- Investigate the dynamic stability capability of VSPSH and assess its impact on grid frequency response and transient stability
- Investigate the PSH contribution to resource adequacy



PSH SCHEDULING TOOL

Goals: Maximize PSH operating profit on a given optimization horizon while respecting operational and scheduling constraints and enabling PSH developers and owners to unlock PSH value from both ancillary services and energy.

- A novel PSH Scheduling tool was developed, incorporating for the first time the impact of variable height differences between reservoirs ('head') and variable speed machine behavior.
- The tool is run in conjunction with a production cost optimization tool to allow for price elasticity effects to be captured.
- Developed in Python open source software and can be easily modified to meet future needs.





PRODUCTION COST MODELING: Base Assumptions

- GE non-proprietary WECC database 2028 study year with 50% renewable penetration
- Economic retirement analysis performed after the renewable additions.
- Simple transmission expansion exercise to alleviate congestion due to generic renewable buildout.
- The base case, referred to as "low storage", includes some PSH and battery storage (8 TWh of PSH, 3 TWh of battery)
- \circ $\,$ Ancillary service modeling:
 - CAISO 2017-2018 IRP production cost model requirements for regulation and spinning reserve
 - $\circ~$ GE MAPS calculates hourly total ancillary service price
 - Historical CAISO prices used to determine how much of the
 - total price for each ancillary product



Average Hourly Ancillary Service Prices





PRODUCTION COST MODELING: High Storage Scenario

- High Storage scenario developed to understand the value of PSH with more storage competition.
- A storage value metric (Annual Revenue \$/Installed Capacity kW) was used to determine when the system begins to be saturated (a 25% decrease was chosen as the "saturation point" for this study)
- When PSH or Battery technologies were added alone, the value metric decreased by 25% when approximately 14 GW were installed.
- Various mixes of PSH and Battery technology were calculated and a 70% PSH (9.8GW, 98GWh) and 30% Battery (4.2 GW, 16.8 GWh) scenario was selected



PRODUCTION COST MODELING: Cases & Outputs





30% Renewable Penetration



DSW

MEX

NWP

Sensitivity - 30% renewables

- Total of 42 cases, low and high storage scenarios with base case and 6 sensitivities
- The PSH plant schedules were revenueoptimized using the scheduling tool developed by GE Global Research.
- Results analyzed for both WECC-wide system impact and individual plant revenue

	Big Chino	San Vicente
Capacity (MW)	2,000	500
Duration(hrs)/ Energy (MWh)	10/20,000	8/4,000
Location	AZ	СА
Revenue Streams	Energy	Energy & Ancillary Services

0%

ALB

BCH

Base - 50% renewables

CAL



PRODUCTION COST MODELING: Results

Delta From Case	Production Cost (\$/M)		CO2 Emissions (million tons)		Simple Cycle Peaker Cycling		Curtailment (GWh)	
without Units	W/ Big Chino	W/ San Vicente	W/ Big Chino	W/ San Vicente	W/ Big Chino	W/ San Vicente	W/ Big Chino	W/ San Vicente
Base Low								
Storage	-182	-62	-1.82	-0.5	-4,762	-1,572	-4,753	-1,102
30% Renewables								
Low Storage	-93	-46	-0.15	-0.24	-5,936	-2,137	-1,406	-550
High Gas Price								
Low Storage	-194	-61	-1.72	-0.46	-4,587	-1,337	-4,790	-1,102
Low Gas Price								
Low Storage	-164	-56	-1.73	-0.43	-4,752	-1,625	-4,666	-1,114
High Hydro Low								
Storage	-184	-56	-1.68	-0.41	-5,676	-1,860	-4,811	-1,115
Low Hydro Low								
Storage	-195	-62	-1.62	-0.45	-5,387	-2,429	-4,399	-1,028
Extreme Low								
Hydro Low								
Storage	-202	-64	-1.55	-0.42	-4,820	-2,182	-4,324	-1,032
Base High								
Storage	-167	-48	-1.65	-0.39	-4,461	-2,132	-4,189	-806
30% Renewables								
High Storage	-58	-28	0.02	-0.07	-3,664	-2,637	-737	-278
High Gas Price								
High Storage	-181	-51	-1.74	-0.44	-4,707	-1,660	-4,312	-845
Low Gas Price								
High Storage	-143	-34	-1.74	-0.27	-3,023	-371	-4,274	-733
High Hydro High								
Storage	-165	-36	-1.71	-0.33	-5,073	-1,851	-4,412	-834
Low Hydro High								
Storage	-181	-48	-1.76	-0.29	-5,793	-1,700	-4,038	-772
Extreme Low								
Hydro High								
Storage	-184	-50	-1.7	-0.39	-5,302	-2,143	-4,118	-863

Positive system impact in all scenarios, no clear winner.

- $\circ~$ Up to \$202M/\$64M reduction in Production Cost
- $\circ~$ Up to 1.82/0.5 million tons of CO2 reduction
- Significant reduction in peak cycling and curtailment reduction



Low Storage
High Storage



PSH plant revenue:

- Highest revenue in high renewable and high gas scenarios
- Reduced by more competing storage and lower renewables



DYNAMIC MODELING: PSLF Models & Benchmarking

- Suite of models added to PSLF to represent variable speed pumped hydro storage units largely based on the models developed as part of a previous DoE project* with minor updates based on GE Hydro's Powerfactory model.
- Benchmarking done against previous DoE project's PSSE model and GE Hydro's Powerfactory model for small test cases
- Reference tests included:
 - \circ Voltage
 - Frequency response
 - Active power
 - Generator loss events
 - Fault response
- Frequency and Fault response of models was ensured to be reasonable for a high renewable WECC case as well.



DYNAMIC MODELING: Assessment at Big Chino Set-Up

- All hours of the year from GE MAPS model filtered to select pinch points in frequency response capability
- The 2022 light load spring case load and generation were scaled to meet the average of these hours
 - MW outputs of generators scaled to meet MAPS area/unit type targets.
 - Loads scaled to meet the MAPS area loads

GE MAPS Model Frequency Pinch Point Criteria

- Spring
- o between 10am and 3pm
- PSH Is pumping greater than 3000 MWh
- Wind + Solar generation > exceeds 60,000 MWh
- load is between 95,000 and 105,000 MWh
- Wind + Solar generation is 73% of load or more





DYNAMIC MODELING: Assessment at Big Chino Results





Event: Trip 2 Palo Verde units Frequency of Big Chino terminal bus

Frequency [Hz]

Output [MW]

Frequency response margin and RoCoF without Big Chino

11.0	FR	FR margin	ROCOF
[MW/0.1Hz]	[MW/0.1Hz]	[MW/0.1Hz]	(between 1 and
			1.125s) [Hz/s]
858	739.73	-118.27	0.31
261.53	42.22	-219.31	0.44
146.04	67.17	-78.87	0.93
149.85	21.22	-128.63	0.27
146.81	347.82	201.015	0.08
	[MW/0.1Hz] 858 261.53 146.04 149.85 146.81	[MW/0.1Hz][MW/0.1Hz]858739.73261.5342.22146.0467.17149.8521.22146.81347.82	[MW/0.1Hz][MW/0.1Hz]858739.73-118.27261.5342.22-219.31146.0467.17-78.87149.8521.22-128.63146.81347.82201.015

Frequency response margin and RoCoF with Big Chino



DYNAMIC MODELING: Additional Results

- Critical Interfaces: Big Chino plant has no measurable impact. Critical outages for these interfaces have no significant impact and the system is stable post-disturbance.
- Fault Response: For a nearby severe three-phase fault, the Big Chino plant:
 - Responds to arrest the voltage decline by increasing its reactive power output and reducing its pumping load.
 - The terminal voltage in the case with Big Chino is higher than in the case without it having a slight positive impact on the system.
 - FSPSH gives greater reactive power contribution during the fault which is good, however once the fault is cleared its output oscillates for longer before settling. VSPSH settles after fault clearance much more quickly.



A Variable Speed PSH unit has a positive impact on grid frequency response and transient stability

CAPACITY VALUE: Approach

- Calculate capacity value of storage, for different ratios of energy/capacity (hours of storage)
- Simulations in GE MARS with same basic assumptions and PSH plants as production cost model
- Impact of wind/solar presence in the system to the capacity value
- Developed new GE MARS version which supports dynamic dispatch of storage
- Loss-of-load expectation (LOLE)-based analysis determined the effective load carrying capability (ELCC) of the incremental storage
- Capacity value is the resource's contribution towards meeting a reliability target.





CAPACITY VALUE: Base Case Results

- Each ELCC calculation was done for 6 years of wind, solar, and load shapes (2007-2012), results are similar
- Results show Capacity Value as a % of nameplate capacity
- Base case results are above 95% with 2 hours of storage in AZ and with 1 hour of storage in CA
- $\circ~$ High renewable penetration caused LOLE to be for periods of ~1 hour





CAPACITY VALUE: Solar Reduction Sensitivities

- \circ Reduction of solar in the system reduces the Capacity Value of PSH at lower storage durations
- Biggest effect shown in CA where PSH CV only reaches ~95% with 4 hours of storage with no solar in the system
- Reduction of solar removes the duck curve, makes risky hours spread across multiple hours, so 1 hour of storage is no longer sufficient to cover all the LOLE



Solar reduction (%) - 0 - 100

As solar is taken out, PSH needs more storage duration to get to 100 CV



STUDY RESULTS AND CONCLUSIONS

- A **novel PSH Scheduling tool** was developed and for the first time incorporated the impact of variable height differences between reservoirs ('head') and variable speed machine behavior.
- **PSH has a positive impact** on reducing production cost, CO₂ emission and curtailment of other renewables in all scenarios even when competing with other storage.
- Two **new VSPSH stability models** have been created and incorporated into PSLF grid planning software so grid operators can assess their benefits.
- **Grid Resiliency**: A 2GW VSPSH plant in Arizona in *pumping mode* was able to markedly improve the frequency response by 50mHz in the US Western Interconnect.
- **Reserve Adequacy**: PSH has substantial capacity value even with short duration.
- Full report can be found at https://www.osti.gov/servlets/purl/1824300



PSH provides value to support power grid needs for generation adequacy, balancing, resiliency and stability. New tools and methods are now available and being deployed to unlock that value.



Project Team

US Department of Energy

Alejandro Moreno Rajesh Dham (Program Manager) Hill (William) Balliet Patrick Soltis Sam Bockenhauer Katie Jackson

GE Global Research

Miaolei Shao (Program Manager) Xian Guo

GE Energy Consulting

Christina Bisceglia (Project Manager) Eduardo Ibanez Shruti D. Rao Slobodan Pajic Mitchel Bringolf

GE Renewable Energy

David Havard



GE Energy Consulting wants to hear from you!



Visit our website

GEEnergyConsulting.com

Join us on Linkedin

Linkedin.com/company/ ge-energy-consulting **Follow us on Twitter** @GEenergyConnect



© 2023 General Electric Company - All rights reserved