



Short-Term Reserve Product in MISO

Yonghong Chen

Consulting Advisor, Market Development


Chen-Hao Tsai

Advisor I, Operations Risk Assessment

Presented at ESIG 2022 Fall Technical Workshop, October 24, 2022

Midcontinent Independent System Operator (MISO) scope of operations

- MISO is an independent, not-for-profit, member-based organization responsible for operating the power grid across 15 U.S. states and the Canadian province of Manitoba.



- MISO's core responsibilities
 - Maintain reliability of bulk electric system
 - Administer Energy and Operating Reserves Market, including a Day-Ahead Market, a Real-Time Market and a Financial Transmission Rights (FTR) market
 - Transmission Expansion Planning

- **MISO numbers**

- 189,421 MW market generation capacity
 - Wind in-service: 28,646 MW
 - Solar in-service: 1,872 MW
- Historic Summer Peak: 127,125 MW
- Historic Winter Peak: 109,336 MW

MISO's Reserve products and mechanisms address uncertainty

| PRODUCT | TIME HORIZON OF UNCERTAINTY TO COVER | UNCERTAINTY ADDRESSED |
|--|---------------------------------------|---|
| Regulating Reserve | Seconds (0-5 minutes) | Uncertainty between real-time dispatch and actual load – intended for normal imbalance within 5-minute intervals |
| Contingency Reserve | 10 minutes post-contingency event | Uncertainty caused by contingencies that create significant and immediate imbalances – NERC required recovery in 15 min |
| Ramp Capability | 10-25 minutes | Uncertainty in upcoming interval due to net load uncertainty and contingencies |
| Short-Term Reserve¹ | Intra-day > 30 minutes, up to 3 hours | Intra-day uncertainty caused by net load uncertainty and contingencies |
| Post-Reserve Deployment Constraints | Applied to STR | Addresses sub-regional and zonal uncertainty |

a. Regulating Reserve Requirement is about 400MW

b. Contingency Reserve Requirement is about 2,010MW

c. Short-Term Reserve Requirement (Effective December 7, 2021) varies by season and hour in a day

[1] Y. Chen, "Addressing Uncertainties Through Improved Reserve Product Design," in IEEE Transactions on Power Systems, 2022

Short-Term Reserve (STR) Fast Facts

- Addresses market-wide, sub-regional and local short-term reserve needs via transparent price signal.
 - Reduce uses of out-of-market commitments in Reliability Assessment Commitment process.
- STR separately cleared in Day-Ahead and Real-Time markets and co-optimized with energy and other reserve products
 - For individual resource, cleared STR capacity may overlap with Contingency Reserve (CR) and Up Ramp Capability Product (RCP)
- Generation, Demand Response Resource Types I and II, Stored Energy Resource Type II, and External Asynchronous Resources may qualify to provide STR
 - Online dispatchable resources, excluding Dispatchable Intermittent Resources (DIR) and Intermittent Resources, may provide online STR
 - Offline resources that can reach their economic minimum output within 30 minutes, sustain output for 60 minutes and have a minimum run time of four hours or less may provide offline STR.

Process of establishing Short-Term Reserve (STR) Requirements


of Non-Intimittent Gen Error (L)



Simulation to establish STR demand curve from three components of uncertainty based on historical operational data

- Non-Intermittent Gen + RegMW
- Gen OU/Derate
- Real-Time Commitment


emand curve clustering of Hour-Month (L)



Establish cluster of hour and season based on simulated STR demand curve

- 3 cluster of Hour (Low/Medium/High)
- 2 season (Summer/Winter)

Winter STR Requirement



Establish seasonal STR requirement based on season and hour cluster

- Normal Day (cover 97.14% risk)
- Additional adder for Tight Day (cover 99% risk)


System-wide Short-Term Reserve Dynamic Requirements for Winter 2022-2023

- Historical data used as input for STR demand curve simulation: [2019/01/01 to 2022/08/01](#)
- Winter season definition based on clustering result: [October to March](#)
- System-wide Normal Day (97.14%): [3500 / 4000 / 4300](#)
- System-wide Tight Day (99%):
Use Normal Day requirement + **800** MW as proxy


| Hour | Label | STRMW 97.14% all Winter | STRMW 99% all Winter |
|------|--------|-------------------------|----------------------|
| 0 | Medium | 4000 | 4800 |
| 1 | Low | 3500 | 4300 |
| 2 | Low | 3500 | 4300 |
| 3 | Low | 3500 | 4300 |
| 4 | Low | 3500 | 4300 |
| 5 | High | 4300 | 5100 |
| 6 | High | 4300 | 5100 |
| 7 | High | 4300 | 5100 |
| 8 | Medium | 4000 | 4800 |
| 9 | Medium | 4000 | 4800 |
| 10 | Medium | 4000 | 4800 |
| 11 | High | 4300 | 5100 |
| 12 | High | 4300 | 5100 |
| 13 | Medium | 4000 | 4800 |
| 14 | Medium | 4000 | 4800 |
| 15 | Low | 3500 | 4300 |
| 16 | Low | 3500 | 4300 |
| 17 | Low | 3500 | 4300 |
| 18 | Low | 3500 | 4300 |
| 19 | Low | 3500 | 4300 |
| 20 | High | 4300 | 5100 |
| 21 | High | 4300 | 5100 |
| 22 | High | 4300 | 5100 |
| 23 | Medium | 4000 | 4800 |

STR Dynamic Requirements cover different distribution of simulated uncertainty in High/Medium/Low hours

Distribution of aggregated uncertainty: Winter Hour 2




Distribution of aggregated uncertainty: Winter Hour 7



For example, Hour 7 is a simulated High uncertainty hour (with longer tail of uncertainty MW) compared with Hour 2 (Low uncertainty hour); hence the STR requirement is set higher for Hour 7.


Dashboards tracking Short-Term Reserve

Tracking STR cleared MW




Tracking STR Requirement against actual realized uncertainty

MISO Systemwide Aggregate Short-Term Uncertainty (MW)
Month selected: April 2022, May 2022, June 2022 and 2 more



Aggregated Uncertainty = Net Input (UDS - LAC) + Outage + Commitment



Ongoing and near-term future improvement

- Filing to Federal Energy Regulatory Commission for enhancing demand curves for the Short-Term Reserve (“STR”) and Up Ramp Capability products
 - Multi-step price range that increases the price of products under increasing degrees of scarcity conditions
- Evaluate and determine if higher granular STR requirement is needed, given the continuous evolving gen fleet/fuel mix in MISO footprint:
 - 4 cluster of Hour
 - 3 or 4 cluster of Season



Questions?