

Impedance Scan Tools for Stability Analysis of IBR Grids

Shahil Shah

Senior Engineer, NREL

Supported by **Wind Energy Technologies Office, DOE**


G-PST/ESIG Webinar

June 30, 2022

Outline

- Control Interactions and Oscillations in IBR Grids
- Impedance-based Stability Analysis Method for Local Interactions
- Scaling the Impedance Method for System Stability Analysis
- NREL's Impedance Scan Software Tool
- NREL's Impedance Measurement System for Utility Scale Wind Turbines and Inverters


Control Interactions/Resonance/Oscillations



System Wide Oscillations in IBR Grids


Australian Grid

7 Hz



Source: Jalali, et. al. (AEMO), CIGRE 2021.

Scotland Grid



• Source: Julian Leslie, G-PST/ESIG Webinar, Jan. 2022.

PSCAD study for 100% IBR operation of Hawaiian Islands


• Source: Hawaiian Electric Island-Wide PSCAD Studies, Electranix, June 2021.

Key Questions: (1) How each of the selected IBRs impact the damping and frequency of oscillation modes? (2) Whether curtailing IBRs will help? (3) Which IBRs must be curtailed? (4) Where to install dampers?

Causes for Stability Problems

Fast, Complex, and Diverse IBR Controls

Declining System Strength



Control systems of IBRs get coupled through network in regions with low system strength because of lower fault current levels and inertia.

Stability analysis is challenging because of complex dynamics and unavailability of open-box models of IBRs

How Mechanical Engineers Solved this Problem?


- Modal Testing, Analysis, and Damping





- German Aerospace Center (DLR)
performs modal testing on aircraft wings

- Damper in Taipei 101 tower (660 tons)


Impedance-Based Stability Analysis Method



- Feedback Loop Gain: $Z_g(s)/Z_i(s)$
- Fundamental Premise: IBR and Grid are Separately Stable**




Scaling the Impedance Method: The Usual Way




- “Isolate” **ALL** IBRs from the network
- Assume network without all IBRs is stable and all IBRs are independently stable
- Requires impedance scan of each IBR as well as scan of the impedance matrix of the network without IBRs from all ports
 - **Is it possible? YES**
 - **Is it scalable? NO**

Reversed Impedance-Based Stability Criterion



Usual Approach



Reversed Approach





Impedance Scan Tool



1. Scan IBR and network impedance
2. Perform stability analysis

Impedance Scan of IBR and Network




- Fully Automated Impedance Scan

- Perturbation frequency, magnitude, recording length are automatically selected
- Postprocessing algorithm automatically synchronizes reference frame, optimizes FFT window length, and minimizes leakage errors
- Outputs impedance scan results in both DQ and sequence domain

0058Hz5.cfg	9/29/2020 11:01 AM	cfg Relay Event file	1 KB
0058Hz5.dat	9/29/2020 11:01 AM	dat Relay Event file	12,696 KB
0058Hz5.hdr	9/29/2020 11:01 AM	hdr Relay Event file	1 KB
0059Hz0.cfg	9/29/2020 11:00 AM	cfg Relay Event file	1 KB
0059Hz0.dat		dat Relay Event file	996 KB
0059Hz0.hdr		hdr Relay Event file	1 KB
0059Hz3.cfg	9/29/2020 10:59 AM	cfg Relay Event file	1 KB
0059Hz3.dat	9/29/2020 10:59 AM	dat Relay Event file	12,696 KB
0059Hz3.hdr	9/29/2020 10:59 AM	hdr Relay Event file	1 KB
0059Hz7.cfg	9/29/2020 10:58 AM	cfg Relay Event file	1 KB
0059Hz7.dat	9/29/2020 10:58 AM	dat Relay Event file	12,696 KB
0059Hz7.hdr	9/29/2020 10:58 AM	hdr Relay Event file	1 KB
0060Hz3.cfg	9/29/2020 10:57 AM	cfg Relay Event file	1 KB



Output Files from Scan

Impedance Scan + PSCAD-PSSE Cosimulation



14-Bus System with High Levels of IBRs


1 Sync. Generator (224 MW); 3 GFM Inverters (90 MW); 2 GFL Inverters (140 MW)




- How to identify the frequency and damping of the 2.5 Hz mode?
- What is the impact and participation of selected IBRs on the 2.5 Hz mode?
- How to estimate the minimum GFM capacity required for stable operation?

Scan at GFM IBR at Bus-6

Network Admittance




IBR Admittance




Impedance Scan Tool Separates the Dynamics of an IBR from the Network

Modal Impedance Analysis for GFM IBR at Bus-6

Magnitude Plot




Nyquist Plot




Modal Parameter	Without IBR	With IBR	Impact of IBR
Frequency (f_r)	2.36 Hz	2.5 Hz	~ 0.12 Hz
Damping Factor (ζ)	-5.932%	13.3%	+19.2%

Analysis at GFM IBR at Bus-3

Magnitude Plot




Nyquist Plot



Modal Parameter	Without IBR	With IBR	Impact of IBR
Frequency (f_r)	2.5 Hz	2.5 Hz	~ 0
Damping Factor (ζ)	-9%	12%	+21%

Analysis at GFL IBR at Bus-2

Magnitude Plot




Nyquist Plot

Modal Parameter	Without IBR	With IBR	Impact of IBR
Frequency (f_r)	2 Hz	2.5 Hz	0.5 Hz
Damping Factor (ζ)	9.25%	15%	+5.75%

Analysis at GFL IBR at Bus-14


Magnitude Plot



Nyquist Plot

Modal Parameter	Without IBR	With IBR	Impact of IBR
Frequency (f_r)	1.28 Hz	2.6 Hz	1.3 Hz
Damping Factor (ζ)	23.5%	19%	-4.5%

Output of Impedance Scan Study



Mode Parameters


f	ζ
2.5 Hz	+12 to 15%

Impact of Different IBRs


IBR	Δf	$\Delta \zeta$
GFM at Bus-6	0.12 Hz	+19.2%
GFM at Bus-3	0 Hz	+21%
GFL at Bus-2	0.5 Hz	+5.7%
GFL at Bus-14	1.3 Hz	-4.5%

Impedance Measurement System at NREL


Injection of Perturbation in Turbine Voltages



Response in Turbine Output Currents



Measured Impedance of a 4 MW Wind Turbine




7-MVA grid simulator



Grid-side transformer Output transformer ARU + 4 NP-VSC in parallel





5-MW dynamometer



Medium-voltage sensing




Impedance Scan of a 4 MW Wind Turbine




Impedance Response for GFM vs GFL Mode


2.2 MVA Battery Inverter



2 MW PV Inverter



2.5 MW Type III Turbine



Impedance Responses show Better Damping for GFM Control Mode

Summary

- Impedance scan tools are critical to understand small-signal stability of IBR grids
- Applications:
 - Identify underdamped or unstable oscillation modes in the system
 - Estimate the role of different IBRs in system oscillations modes
 - Identify IBRs most suitable for implementing damping solutions
 - Estimate the capacity of grid-forming resources required for stability
 - Online estimation of system inertia in a noninvasive manner
 - ...
- Ongoing Developments at NREL
 - Reduced time required for impedance scans and post-processing of scan data
 - Impedance estimation from transient data obtained from fault recorders and PMUs
 - Intelligent selection of perturbation levels to improve signal-to-noise ratio


Development Team



Shahil Shah




Przemek
Koralewicz



Weihang Yan




Vahan
Gevorgian



Emanuel Mendiola



Robb Wallen



Thank you!

www.nrel.gov

Shahil.Shah@nrel.gov

This work was authored by Alliance for Sustainable Energy, LLC, the manager and operator of the National Renewable Energy Laboratory for the U.S. Department of Energy (DOE) under Contract No. DE-AC36-08GO28308. Funding provided by U.S. Department of Energy Office of Energy Efficiency and Renewable Energy Wind Energy Technologies Office. The views expressed in the article do not necessarily represent the views of the DOE or the U.S. Government. The U.S. Government retains and the publisher, by accepting the article for publication, acknowledges that the U.S. Government retains a nonexclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for U.S. Government purposes.

